

Addendum #1

City of Bardstown Public Works Building

Issue Date: September 15, 2020

Bid Date: Thursday, September 24, 2020 Time: 10:00am

This Addendum forms a part of the Contract Documents and acknowledgement of receipt of this Addendum must be applied in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

This Addendum <u>modifies the original bid date to the time listed above</u> and modifies the original Bidding Documents dated September 17, 2020.

This Addendum consists of **2** page(s) and <u>no</u> drawings.

CHANGES / CLARIFICATIONS TO BID DOCUMENTATION

- 1. Due to concerns about larger state projects being bid on the same date, the city has opted to push the bid date back to the date and time listed above.
- 2. With the change in bid date. The last day for questions had been changed to end of work day, Tuesday September 22, 2020.
- 3. The elevations are a bit confusing on the roof finishes and are in conflict with the wall sections. Change the roofs to be as follows. The Lower (Office) Roof is to be Pre-Painted Standing Seam Roof. The Upper (Garage) Roof is to be Galvalume Standing Seam Roof.
- 4. It has been determined that due to the rising cost of wood, it will be acceptable to build the office portion out of metal and include this cost change as part of the base bid. If this option is used, it must be noted on the bid form in the section listed as "Substitutions" but if the cost is include in the base bid, no total will be required in the list. If this option is included it will be the responsibility of the contractor to include all design modifications necessary to support these changes.

CHANGES / CLARIFICATIONS TO ROOM, DOOR AND WINDOW SCHEDULES

1. The note #1 under door schedule remarks should say glazing to be as shown in elevations. Remove "Full Glazed".

CHANGES / CLARIFICATIONS TO SPECIFICATIONS

1. The overhead door shall receive standard vision panels and not the double pane, low-e as specified in the drawing specifications.

 At the request of the owners, the vehicle lift listed in section 14450 shall be changed to a (2) post, 25,000lbs (25k lbs.) lifting capacity unit of similar specifications by the manufacturer or approved equal.
END OF ADDENDUM #1
I:\2019\19-3060 City of Bardstown Public Works Building\Documents\Bid Documents\Addendums\City of Bardstown Public Works Addendum #1 - 2020-09-15.docx