
# FiveStar Store #8718

# NEWCOMB OIL CO., LLC.

636 S. DIXIE BLVD.
RADCLIFF KY 40160



### **ARCHITECT:**

KEYES ARCHITECTS AND ASSOCIATES
4717 PRESTON HIGHWAY
LOUISVILLE, KENTUCKY 40213
PH: (502) 636-5113
CONTACT:HAROLD COX, PROJECT MANAGER
EMAIL:HCOX@KEYESARCHITECTS.COM
ARCHITECT: CHARLES J. KEYES III

### **GENERAL CONTRACTOR:**

BCD, INC.
1962 FILIATREAU LANE
BARDSTOWN, KENTUCKY 40004
PH: (502) 348-2305
WEB: www.bcdinc.com
EMAIL:

### MEP ENGINEERS

CMTA Engineering Consultants
10411 MEETING STREET
PROSPECT, KENTUCKY 40059
PH: (502)-326-3085
WEB: cmtaengrs.com
EMAIL:

### <u>OWNER</u>

NEWCOMB OIL COMPANY, LLC. 951 WITHROW CT. BARDSTOWN, KENTUCKY 40004 PH: (502)-348-3961

### **CONSULTING ENGINEER**

RICHARD BARRIOS
10202 WORTHINGTON LANE
PROSPECT, KENTUCKY 40059
PH: (502)-873-5741
RICHARD BARRIOS
EMAIL: rbarrios6@att.com




# PROJECT INFORMATION APPLICABLE BUILDING CODES BUILDING CODE BUILDING CODE ACCESSIBILITY CODE ENERGY CODE ENERGY CODE USE AND OCCUPANCY: M - MERCANTILE CONSTRUCTION TYPE: V-B BUILDING INFORMATION BUILDING: 5,000 s.f. TOTAL BUILDING SIZE: 5,000 s.f. FIRE SUPPRESSION: NONE


OCCUPANCY ALLOWANCE							
FUNCTION OF SPACE	ALLOWANCE	AREA	OCCUPANCY				
MERCANTILE	60 GROSS	5,000	83				
TO	83						

RE\	/ISIOI	NS:	NOTE SYMBOL
	00-00-00		

	Sheet List Table
Sheet Number	Sheet Title
T1.01	Title Sheet
Foundation Plans	& Details
F1.01	Foundation Plan
F2.01	Foundation Details
Structura	I
S1.01	General Notes
S1.02	Structural Details
S1.03	Structural Details
S1.04	Low Roof Plan
S1.05	Structural Misc. Details
S1.06	Structural Sections & Details
S1.07	Structural Sections & Details
S1.08	Structural Sections & Details
Floor Pla	ns
A1.01	Floor Plan
A1.02	Dimension Floor Plan
A1.03	Equipment & Casework Plan
A1.04	Finish Plan
A1.05	Reflected Ceiling Plan
A1.06	Roof Plan
	Elevations
A2.01	Exterior Elevations
A2.02	Exterior Elevations
A2.03	Interior Elevations
A2.04	Interior Elevations
A2.05	Interior Elevations
A2.06	Interior Elevations
	s and Standards
	_ Schedules
A3.04 Details &	
A5.01	Building Sections
A5.02	Building Sections & Details
A5.03	Wall Sections & Details
A5.04	Wall Sections & Details
A5.05	Wall Sections & Details
A5.06	Wall Sections & Details
A5.07	Wall Sections & Details
A5.08	_ Wall Sections & Details

Mechanica	al
M1.01	
M2.01	Floor Plan
M3.01	Mechanical Sections and Details
Electrical	
E1.00	
E2.00	Electrical Lighting
E3.00	Electrical Power & Systems
E4.00	Electrical Riser Diagram
E5.00	Electrical Schedules
Plumbing	
P1.01	Plumbing Legend & Details
P2.01	Floor Plan - Sanitary, Waste &
1 2.01	Vent
P2.02	Floor Plan - Water & Gas
Specificati	ons
SP1.01	
SP1.02	Specifications
SP1.03	Specifications
SP1.04	Specifications





5. DO NOT ADD WATER O CONCRETE DURING DELIVERY. WATER MAY BE ADDED ON SITE ONLY IF A TICKET WITH THE WATER UNDER RUN NOTED

SPECIFICATIONS AFTER THE WATER IS ADDED. CONCRETE ADMIXTURES OF ANY KIND SHALL NOT BE ADDED ON SITE OOR DURING DELIVERY.

IS PROVIDED. WATER ADDED MUST NOT EXCEED THE AMOUNT OF WATER NOTED ON THE TICKET. CONCRETE MUST STILL MEET

6. CLEAR COVER FOR STEEL REINFORCEMENT

6.1. IN EXTERIOR FACE OF CONCRETE = 3"

6.2. IN INTERIOR FACE OF CONCRETE = 1.5"

**GENERAL NOTES:** 

1. BEFORE PLACING CONCRETE, INSPECT AND COMPLETE FORMWORK INSTALLATION. VERIFY REINFORCING STEEL PLACEMENT, SIZES, SPLICES AND EMBEDS TO BE CAST IN.

2. COMPLY WITH ACI 304R "RECOMMENDED PRACTICE FOR MEASURING, MIXING, TRANSPORTING AND PLACING CONCRETE".

3. DEPOSIT AND CONSOLIDATE CONCRETE IN FORMS IN HORIZONTAL LAYERS NOT DEEPER THAN 18" AND IN A MANNER TO PREVENT INCLINED

4. DEPOSIT AND CONSOLIDATE SLABS IN A CONTINUOUS OPERATION WITHIN LIMITS OF CONSTRUCTION JOINTS UNTIL PLACEMENT OF PANEL OR

SECTION IS COMPLETED. 5. PROTECT CONCRETE FROM PHYSICAL DAMAGE OR REDUCED STRENGTH WHICH COULD BE CAUSED BY FROST, FREEZING ACTIONS OR LOW

6. WHEN HOT WEATHER CONDITIONS EXIST THAT WOULD IMPAIR QUALITY AND STRENGTH OF CONCRETE, PLACE CONCRETE IN COMPLIANCE WITH ACI 305R. CONCRETE AT TIME OF PLACEMENT SHALL BE LESS THAN90 DEF "F" AND SHALL BE MAINTAINED SO THAT THE TEMPERATURE DOES NOT EXCEED 90 DEF "F".

7. CONSOLIDATE CONCRETE BY MECHANICAL VIBRATING EQUIPMENT SUPPLEMENTED BY HAND-SPADING OR RODDING OR TAMPING. DO NOT USE VIBRATORS INSIDE FORMS. DO NOT INSERT VIBRATORS INTO LOWER LAYERS OF CONCRETE THAT HAVE BEGUN TO SET.

FINISH OF HORIZONTAL CONCRETE SURFACES: 1. EXTERIOR SLABS UNDER CANOPY SHALL RECEIVE A FINE BROOM FINISH. APPLY A TROWEL FINISH, STOPPING AFTER A SECOND TROWELING,

AND WHEN CONCRETE IS STILL PLASTIC, SLIGHTLY SCARIFY SURFACEWITH FINE BROOM. 2. INTERIOR SLABS SHALL RECEIVE A TROWEL FINISH, APPLY HARD TROWEL FINISH TO SLAB ON GRADE.

3. WATER SHALL NOT BE APPLIED TO HORIZONTAL SURFACES TO RETEMPER PRIOR TO FINISHING.

4. DRY CEMENT SHALL NOT BE ADDED TO HORIZONTAL SURFACES TO STIFFEN SURFACE PRIOR TO FINISH.

5. CONTROL JOINTS FOR SIDEWALKS HAL BE PROVIDED BY SAW CUTTING TO A MINIMUM DEPTH OF 1/4" x SLAB THICKNESS. ELIMINATE TOOL MARKS ON CONCRETE SURFACES.

CONCRETE CURING AND PROTECTION:

TEMPERATURES IN COMPLIANCE ACI 306R.

CONCRETE PLACEMENT:

1. PROTECT CONCRETE FROM PREMATURE DRYING AND EXCESSIVE COLD OR HOT TEMPERATURES.

2. START INITIAL CURING IMMEDIATELY AFTER FINAL FINISHING IS COMPLETE. CURE CONCRETE WITH KURE N HARDEN BY SONNERBORNE.

QUALITY CONTROL TESTING OF CONCRETE DURING CONSTRUCTION: 1. THE OWNER MAY RETAIN A TESTING LABORATORY TO PERFORM TESTS AND TO SUBMIT TEST REPORTS. THE CONTRACTOR SHALL ALLOW TESTING AGENCY ACCESS TO ALL MATERIALS AND SHALL ASSIST IN OBTAINING SAMPLES.

2. TESTING AGENCY HAS THE AUTHORITY TO REJECT A LOAD OF CONCRETE THAT DOES NOT MEET SPECIFICATIONS. REJECTED CONCRETE SHALL BE REPLACED AT NO COST TO THE OWNER.

STRUCTURAL STEEL:

1. STRUCTURAL STEEL HAS BEEN DESIGNED AND SHALL BE FABRICATED AND ERECTED IN ACCORDANCE WITH THE AISC SPECIFICATION FOR THE STRUCTURAL STEEL BUILDINGS 15TH ADDITION.

2. ALL MATERIALS SHALL CONFORM TO THE FOLLOWING SPECIFICATIONS: LATEST EDITIONS OF THE 2018 KENTUCKY BUILDING CODE SHALL BE

STRUCTURAL WIDE FLANGE SHAPES

INCLUDING COLUMNS, BEAMS, ETC. ASTM A992 STRUCTURAL ANGLES, CHANNELS, PLATE & MISC. ITEMS ASTM A36 ANCHOR BOLTS A36 OR A307 STRUCTURAL TUBING & PIPE ASTM A500, GRADE "B" WELDING ELECTRODES E70XX

3. ALL BOLTED CONNECTIONS SHALL BE DESIGNED BY THE FABRICATOR IN ACCORDANCE WITH THE "SPECIFICATION FOR STRUCTURAL JOINTS USING ASTM A325 BOLTS" USING 3/4" INCH DIAMETER BOLTS. WASHERS SHALL BE LOAD INDICATOR TYPE OR BOLTS SHALL BE TENSION CONTROL TYPE.

4. ALL WELDING SHALL BE IN ACCORDANCE WITH "THE STRUCTURAL WELDING CODE" AWS D1.1.

5. ALL CONNECTIONS SHALL BE DESIGNED FOR 1/2" OF THE MAXIMUM UNIFORM LOAD FOR THE SIZE, SPAN, AND GRADE OF STEEL LISTED IN TABLE 3-6 "MAXIMUM TOTAL UNIFORM LOAD" FROM THE3 AISC MANUAL (15TH EDITION) UNLESS OTHERWISE NOTED.

6. ALL CONDITIONS AND DIMENSIONS PRIOR TO FABRICATION AND ERECTION OF STEEL SHALL BE VERIFIED. ANY AMBIGUITY FOUND SHALL BE

IMMEDIATELY BROUGHT TO THE NOTICE OF NEWCOMB OIL COMPANY. 7. GROUT SHALL BE PRE-MIXED, NON-METTALIC, NON-CORROSIVE, NON-STAINING PRODUCT CONTAINING SELECTED SILICA SANDS, PORTLAND,

CEMENT, SHRINKAGE COMPENSATING AGENTS, PLASTICIZING AND WATER REDUCING AGENTS, COMPLY WITH CE-CRD-C621. 8. BEFORE SHIPPING FROM THE STEEL SHOP ALL STEEL SHALL BE CLEANED. REMOVE HEAVY RUST AND MILL SCALE, SPATTER, SLAG OR FLUX

DEPOSITS. COMPLY WITH STEEL FABRICATORS SP-3 "POWER TOOL CLEANING". REMOVE OIL, GREASE AND SIMILAR CONTAMINATES; COMPLY WITH SSPC SP-1 "SOLVENT CLEANING".

9. IMMEDIATELY AFTER CLEANING APPLY MANUFACTURERS OR FABRICATOR'S STANDARD, FAST CURING, LEAD FREE, UNIVERSAL MODIFIED ALKYD PRIMER SELECTED FOR GOOD RESISTANCE TO NORMAL ATMOSPHERIC CORROSION, FOR COMPATIBILITY WITH ALKYD FINISH PAINT SYSTEMS, AND FOR THE CAPABILITY OF PROVIDING A SOUND FOUNDATION FOR FIELD APPLIED TOPCOATS DESPITE PROLONGED EXPOSURE. APPLICATION SHALL BE NOT LESS THAN 1.5 MILS. DRY FILM THICKNESS.

STEEL JOISTS:

1. ALL STEEL JOISTS, JOIST GIRDERS, REQUIRED ACCESSORIES SHALL BE DESIGNED, DETAILED AND FABRICATED IN ACCORDANCE WITH THE "STANDARD SPECIFICATIONS FOR OPEN WEB STEEL JOISTS. ACCORDING TO THE STEEL JOIST INSTITUTE". CURRENT EDITIONS SHALL APPLY.

2. PROVIDE JOISTS FABRICATED IN COMPLIANCE WITH THE STEEL JOIST INSTITUTE (SJI) STANDARD SPECIFICATIONS, LOAD TABLES AND WEIGHT TABLES FOR: OPEN WEB STEEL JOISTS (K-SERIES) AND LONGSPAN STEEL JOISTS (LH SERIES).

3. EXTENT OF WORK IS INDICATED ON THE PLANS INCLUDING BASIC LAYOUT AND TYPE OF JOISTS REQUIRED. UNLESS OTHERWISE INDICATED, THE FOLLOWING ITEMS ARE INCLUDED: STEEL JOISTS, JOIST EXTENDED ENDS, CEILING EXTRUSIONS, EXTENDED BOTTOM CHORES USED AS STRUTS, BRIDGING AND BRIDGING ANCHOR, JOIST BOTTOM CHORD BRACING, JOIST WALL AND BEAM ANCHORS, HEADERS, LOOSE BEARING PLATES AND ANCHOR BOLTS FOR PLACEMENT.;

4. JOISTS SHALL BE DESIGNED BY JOIST MANUFACTURER TO INSURE THAT CHORD MEMBERS ARE SUFFICIENT TO WITHSTAND FORCES INDICATED ON THE DRAWINGS. ALL JOISTS SHALL BE REVIEWED AND SEALED BY A LICENSED ENGINEER REGISTERED IN THE STATE OF TENNESSEE. JOISTS MANUFACTURER SHALL DESIGN CONNECTIONS ON SHOP DRAWINGS. CONNECTION DESIGN SHALL BE COORDINATED WITH THE STRUCTURAL STEEL FABRICATOR. ALL WELDS OR BOLTS REQUIRED SHALL BE CLEARLY INDICATED.

5. DESIGN AND FABRICATE STEEL JOISTS IN ACCORDANCE WITH SJI SPECIFICATIONS, INCLUDING HEADERS AND OTHER SUPPORT FRAMING. VERIFY DRAWING DIMENSIONS AND FIELD CONDITIONS PRIOR TO FABRICATION.

6. PROVIDE HORIZONTAL OR DIAGONAL TYPE BRIDGING FOR JOISTS, COMPLYING WITH SJI "SPECIFICATIONS". PROVIDE BRIDGING ANCHORS FOR ENDS OF BRIDGING LINES TERMINATING AT WALLS OR BEAMS.

7. PROVIDE END ANCHORAGES TO SECURE JOISTS TO ADJACENT CONSTRUCTION, COMPLYING WITH SJI "SPECIFICATIONS", UNLESS OTHERWISE INDICATED.

8. CAMBER JOISTS TOM ALLOW FOR DEAD-LOAD DEFLECTION AS PROVIDED IN THE SJI "STANDARD SPECIFICATIONS".

9. REMOVE LOOSE SCALE, HEAVY RUST, AND OTHER FOREIGN MATERIALS FROM THE FABRICATED JOISTS AND ACCESSORIES BEFORE APPLICATION OF SHOP PAINT. APPLY ONE COAT SHOP COAT OF PRIMER TO STEEL JOISTS AND ACCESSORIES, BY SPRAY. OR OTHER METHOD WHICH COMPLIES WITH STEEL STRUCTURES PAINTING COUNCIL SPECIFICATION, SSPC NO. 15.

STEEL DECKING:

1. COMPLY WITH PROVISIONS OF THE FOLLOWING CODES AND STANDARDS, EXCEPT AS OTHERWISE INDICATED OR SPECIFIED:

A. ANSI "SPECIFICATION FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS"

B. AWS "STEEL WELDING CODE".

C. SDI "DESIGN MANUAL FOR FLOOR AND ROOF DECKS".

2. PROTECT DECKING FROM CORROSION (WHITE RUST), DEFORMATION AND OTHER DAMAGE DURING DELIVERY, STORAGE AND HANDLING. STORE DECKING ON WOOD SLEEPERS WITH SLOPE FOR POSITIVE DRAINAGE. DECKING SHALL BE FREE OF CORROSION (WHITE RUST) PRIOR TO

3. BASIC STEEL SHALL BE FLAT ROLLED, GALVANIZED SHEETS OF STRUCTURAL QUALITY, MEETING THE REQUIREMENTS OF ASTM A653. GALVANIZING SHALL MEET ASTM A924, G90 COATING. STEEL BLOCK SUPPLIER TO PROVIDE GALVANIZED DECK WHICH IS SHOP AND FIELD

4. ROOF DECKING SHALL BE A MINIMUM OF 20 GAUGE METAL DECK, TYPE "B" WIDE RIB, WITH A FABRICATED DEPTH OF 1-1/2" INCHES. FORM DECK UNITS IN LENGTHS TO SPAN 3 OR MORE SUPPORTS, WITH FLUSH, TELESCOPED OR NESTED 2" LAPS AT ENDS AND SIDE LAPS, UNLESS

5. FABRICATE METAL DECKING IN ACCORDANCE WITH SDI DESIGN MANUAL TO ACCOMMODATE MAXIMUM WORKING STRESS OF 0.6FY AND MAXIMUM SPAN DEFLECTION OF L/240. FOR ROOF DECKING, MAXIMUM FIBER STRESS SHALL NOT EXCEED 20,000 PSI UNDER A TOTAL DEAD AND LIVE LOAD OF 50PSF AND DEFLECTION SHALL NOT EXCEED L/360 OF THE SPAN UNDER A LIVE LOAD OF 25 PSF. FOR FLOORING DECKING, MAXIMUM FIBER STRESS SHALL NOT EXCEED 0.6FY UNDER A TOTAL DEAD AND LIVE LOAD OF 150 PSF AND DEFLECTION SHALL NOT EXCEED L/360 OF THE SPAN UNDER LIVE LOAD OF 100 PSF.

6. ERECT AND ATTACH METAL DECKING IN ACCORDANCE WITH SDI DESIGN MANUAL FOR FLOOR AND ROOF DECK, AS WELL AS WITH MANUFACTURER'S RECOMMENDATIONS AND FINAL SHOP DRAWINGS. PROVIDE WELDING IN ACCORDANCE WITH SDI SPECIFICATIONS AND

7. STEEL ROOF DECK UNITS SHALL BE ANCHORED TO SUPPORTING STRUCTURAL STEEL MEMBERS TO PROVIDE LATERAL STABILITY TO THE TOP FLANGE OF THE SUPPORTING STRUCTURAL MEMBERS AND TO RESIST UPLIFT WIND FORCES INDICATED ON THE PLANS. THE DEAD LOAD OF THE ROOF DECK CONSTRUCTION PLUS THE DEAD LOAD OF THE ROOFING MATERIAL PLUS RIGID INSULATION MAY BE DEDUCTED FROM THE SPECIFIED UPLIFT FORCES.

8. INSTALL 6" INCH WIDE 18ga SHEET STEEL COVER PLATES WHERE DECK CHANGES DIRECTION. SCREW IN PLACE 12" INCHES ON CENTER

9. AFTER DECKING INSTALLATION, WIRE BRUSH, CLEAN AND PAINT SCARRED AREAS, WELDS AND RUST SPOTS ON TOP AND BOTTOM SURFACES OF DECKING UNITS AND SUPPORTING STEEL MEMBERS. TOUCH UP GALVANIZED SURFACES WITH GALVANIZING REPAIR PAINT APPLIED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.

PROJECT NO:

20-4047 DRAWN BY:

HWC/

DATE: 8/30/2020



Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

GENERAL NOTES

(2) 3/4"Øx8" ASTM A108 HÉADED STUDS @ EA. BEARING LOCATION

TYP. WIDE FLANGE, HSS, AND JOIST BEARING PLT. DET.

PROVIDE (2) #5 ON #5 DOWELS @ 12" O.C. BOTH SIDES OF OPENING (TYP.) W/ 180° HOOK @ BOTT. JAMB DOWELS SHALL BE CONT. TO FOOTING (2) #6 LINTEL REINF. w/ STD HOOK (TYP.) (1) #6 LINTEL REINF. w/ STD HOOK (TYP.) 4'-3" MAX.

TYP. REINFORCEMENT @ HVAC OPENING IN ICF


PROVIDE (2) #5 ON #5 DOWELS @ 12" O.C. BOTH SIDES OF OPENING (TYP.) W/ 180° HOOK @ BOTT. PROVIDE #5 IN TWO ADJACENT CELLS ON BOTH SIDES OF DOOR -OPENING (TYP.) (2) #6 LINTEL REINF. w/ STD HOOK (TYP.) #4 - 24" #5 - 30" JAMB DOWELS SHALL BE #6 - 36" *—* CONT. TO FOOTING MIN. DEVELOPMENT LENGTH - TYP.

TYP. AROUND DOOR/STOREFRONT OPENING IN ICF

(1) LAYER OF 6 MIL.VAPOR BARRIER

OVER 4" OF COMPACTED #57 STONE (AS REQ'STD BY THE OWNER).

TYP. SLAB ON GRADE, SUB-GRADE, VAPOR BARRIER AND CONTROL JOINT




TYP. JOIST REINFORCEMENT


SCALE: 3" = 1'-0"




**BRICK LINTEL** 




TYP. WALL CORNER REINFORCEMENT DETAIL



TYP. STEEL COLUMN BASE DETAIL



TYP. HSS 4x4 BASE PLATE DETAIL



O9 TYP. SIDEWALK DETAIL

SCALE: 3" = 1'-0"

Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

STRUCTURAL DETAILS


PROJECT NO:


20-4047 DRAWN BY:

HWC/ DATE:


8/30/2020


**S1.02** 








**S1.04** 












PROJECT NO: 20-4047 DRAWN BY:


HWC/

8/30/2020

DATE:

Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered & DETAILS proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208






PROJECT NO:

20-4047 DRAWN BY:

obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208



EQUIPMENT SCHEDULE NO QTY EQUIPMENT CATEGORY MANUFACTURER MODEL NUMBER OFOI OFCI CFCI WALK-IN COOLER OUTDOOR CONDENSING UNIT BEER CAVE WALK-IN COOLER OUTDOOR CONDENSING UNIT MULTI-DECK ISLAND MERCHANDISER OUTDOOR CONDENSING UNIT NOT USED 4 WELL HOT FOOD TABLE HOT FOOD MERCHANDISER 120V-1550 WATTS TURBOFAN G32D5 CONVECTION OVEN/WITH HOLDING CABINET FLOOR MODEL GAS FRYER SOLSTICE SG14 SS BASE CABINET W/ ROLLERS CAPTIVE AIRE EXHAUST HOOD WALK-IN FREEZER OUTDOOR CONDENSING UNIT DELI WALK-IN OUTDOOR CONDENSING UNIT REMOTE ICE MAKER (INSTALLED ON FOUNTAIN) N1322R-32A OUTDOOR REMOTE CONDENSER WORKTOP SOLID DOOR FREEZER TWT-48F-HC FOOD PREP TABLE ΓSSU-48-12 SODA FOUNTAIN TEA BREWER FREAL MIXER SINGLE DOOR FREEZER FREAL FREEZER FREEZE MACHINE TAYLOR CROWN COFFEE MAKER MICROWAVE INDUCTION RANGE BAKED GOODS DONUT CASE FRAPP MACHINE CHOC. CAPPU MACHINE CAPPUCCINO MACHINE THERMAL POTS CREAMER PAN CABINET HAND SINK, INTERGAL WITH COUNTERTOP WATER FILTER CSR QUAD-MC SYSTEM DISHWASHER RINSE TABLE - INTREGAL SINK W/DISPOSAL 3-COMPARTMENT SINK 3B184-2D18-16GA FAUCET - WALL MOUNTED WITH 12" SWING EAGLE - METAL MASTERS WALL MOUNT SHELVING (14" X 36") HAND SINK - WALL HUNG MANSFIELD GRAND ISLE 2018HBNS VITREOUS CHINA AMERICAN STANDARD RELIANT 3 - 7385.004 POS TERMINALS WIRE SHELVING (18" X 36") W/ROLLERS EAGLE - METAL MASTERS WIRE SHELVING (24" X 36") W/ROLLERS EAGLE - METAL MASTERS SUSPENDED TV MONITORS

PROJECT NO:

20-4047

HWC/

DATE:

DRAWN BY:

8/30/2020

Keyes Architects and Associates expressly reserve its common law copyright and EQUIPMENT & other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

CASEWORK PLAN

FLOOR FINISH SCHEDULE

T-CODES = TILES USED ON FLOORS. WALL TILES MAY BE FOUND ON INTERIOR ELEVATIONS

FT1- 12 x 12 PORCELAIN STONE TILE / #VL78 - ACCENT BROWN WITH 3/16" GROUT LINES - BRICKWORK PATTERN WITH #145 LIGHT SMOKE SANDED

MAIN TILE FIELD B -

FT2]- 6 X 24 COLORBODY PORCELAIN TILE / #HHO3 TEAK WITH 3/16" GROUT LINES - WITH #59 SADDLE BROWN SANDED GROUT.

1. TILE TO RUN CONTINUOUS UNDER CABINETS. 2. "GROUT BOOST" TO BE USED TO MIX GROUT INSTEAD OF WATER.

### **SHEET NOTES:**

NOTE SYMBOL

1 APPLY "MASTERKURE HD 200WB", TYPICAL TO ALL FLOORS WHERE NOTED

2 THROUGHOUT RESTROOM AREA, REFER TO INTERIOR ELEVATIONS FOR MORE INFORMATION.

3 REFER TO INTERIOR ELEVATIONS

4 NO TILE BEHIND SHELVING.

APPLY "MASTERKURE ND 200WB" TO ALL EXTERIOR SIDEWALKS, EQUIPMENT PADS AND DUMPSTER PADS.

6 PAINT ROOF LADDER.

7 PAINT WALL PER INTERIOR FINISH SCHEDULE - SEE A3.04 FOR MORE INFORMATION

8 EPOXY COATED FLOORS, WHERE NOTED

PROJECT NO:


20-4047 DRAWN BY:

HWC/

8/30/2020

DATE:

Keyes Architects and Associates expressly reserve its common law copyright and FINISH PLAN other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208



**SHEET NOTES:** 

20-4047 CEDAR WOOD BEAMS: BEAMS SHALL BE SEALED WITH CLEAR SEALER, TOPS OF CEDAR BEQAMS

DRAWN BY: HWC/

PROJECT NO:

DATE:

8/30/2020

SIMPSON ICFVL-W LEDGER CONNECTION SYSTEM AT 48" O.C. CONNECT PER -MANUF. INSTRUCTIONS 2X6 LEDGER W/ (2) 1/4"x3 SIMPSON 2X6 LEDGER — SDS SCREWS INTO EACH WALL STUD 2X6 CEILING JOIST @16" O.C. 10'-0" SPAN MAX GYP. BD. CLG. SIMPSON LU24 HANGER TYP ICF WALL ── WOOD STUD WALL


O2 GYP. BD. CLNG. FRAMING


SCALE: 3/4" = 1'-0"





Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered PLAN proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208






Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

EXTERIOR ELEVATION

A2.01



ALUMINUM STOREFRONT: AS MANUFACTURED BY TRULITE 2" X 4-1/2" THERMALLY BROKEN, DARK BRONZE ANODIZED, CENTER GLAZED

1" INSULATED, SOLAR BRONZE, (HEAT STRENGTHENED) OVER "GUARDIAN SUNGUARD SN-68". FULLY TEMPERED BOTH LIGHTS AS REQUIRED BY CODE.

1" INSULATED, DARK BRONZE, "CITADEL GLAZEGUARD 1000 WR", • PRE-FINISHED TEXTURED ALUMINUM SKINS .010", HIGH DENSITY POLYPROPYLENE STABILIZERS, EXPANDED POLYSTYRENE FOAM (EPS) CORE 5/8"

### EXTERIOR FINISH SCHEDULE MANUFACTURER NOTES COLOR/TYPE

			NOTES
E)//	EXTERIOR BRICK	COLOR:"CHARLESTON WELLINGTON"	SIOUX CITY
EX1		TYPE: MODULAR BRICK	
EV0	EXTERIOR BRICK	COLOR:"WHITE PLAINS"	SIOUX CITY
EX2		TYPE: MODULAR BRICK	
EV0	METAL PARAPET CAP (RED)	COLOR:#PATRIOT RED (METALLIC)	METAL SALES
EX3		TYPE: 24GA. KYNAR FINISH	
EV4	METAL FASCIA (GREY)	COLOR:#MYSTIC PLUS	METAL SALES
EX4		TYPE: 24GA. KYNAR FINISH	
EV.	METAL ROOF (RED)	COLOR:#PATRIOT RED (METALLIC)	METAL SALES
EX5	'TEE PANEL' STANDING SEAM ROOF	TYPE: 24GA. KYNAR FINISH	
EV0	METAL CANOPY (RED)	COLOR:#PATRIOT RED METALLIC	TENNESSEE VALLEY METALS
EX6	(DECKING&D.S., GREY)	COLOR:#MYSTIC PLUS	GALVANIZED
EV7	ALUMNIUM STOREFRONT	SEE NOTES BELOW	
EX7			
	GLAZING	SEE NOTES BELOW	
	INSULATED MTL PANEL	SEE NOTES BELOW	
•			

### EXTERIOR ELEVATIONS GENERAL NOTES

- PROVIDE MATERIAL COLOR & FINISH SAMPLES FOR APPROVAL (BY OWNER)
   PROVIDE LOW WEEP VENTS IN VENEER MASONRY, 24" O.C. MAX. USE 3/8" HONEYCOMB
- 3. MASONRY EXPANSION JOINTS: PROVIDE SANDED SEALANT (MATCH MORTAR) W/
  COMPRESSIBLE BACKER. SEALANT TO COMPLY W/ ASTM C290, CLASS 50 SPECIFICATIONS.
  4. SIGNAGE: COORDINATE SIGN SIZE, POWER REQUIREMENTS, AND LAYOUT WITH SUPPLIER
  PRIOR TO INSTALLATION OF STOREFRONT.
  5. CANOPY: REFER TO STRUCTURAL FOR REQUIRED LOADING. CANOPY & DOWNSPOUTS SHOWN
  FOR REFERENCE. FINAL DESIGN & DETAILING BY CANOPY SUPPLIER. SUBMIT TO OWNER

- FOR APPROVAL.

  6. ALL DOWNSPOUTS TO BE SLEEVED AND ROUTED BELOW GRADE. COORDINATE WITH CIVIL FOR COLLECTION AND MANAGEMENT OF WATER ON SITE.

  FOR COLLECTION AND MANAGEMENT OF WATER ON SITE.

  CONTROL OF THE PROPERTY OF THE
- GUTTERS SHALL BE TESTED FOR LEAKS BY DAMNING ALL DOWNSPOUTS AND FILLING GUTTERS WITH 2" (APPROX.) OF
- 8. REFER TO FINISH SCHEDULE FOR HM DOOR AND FRAME PAINT COLORS.

8'-0"

NEWC

PROJECT NO: 20-4047 DRAWN BY:

HWC/ DATE:


8/30/2020


Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

EXTERIOR ELEVATIONS

-METAL HIP ROOF PTD. MTL. EAVE, SOFFIT & FASCIA MASONRY EXP. JOINT AT CHANGE IN PLANE (EX3)— —PTD. MTL. GUTTER (EX4)-MTL. CLAD INFILL PANEL W/ 3/4" EXT. GR. PLYWD. MASONRY EXP. JOINT PTD. MTL. PARAPET CAP & FASCIA, CORE FOR MOUNTING OF OWNER SUPPLIED SIGN. AT CHANGE IN PLANE -REFER TO DETAILS, SHEET A-551 COORD. W/ SIGN SUPPLIER & OWNER. SIGN IS FOR ADDITIONAL INFORMATION INTERNALLY LIT., SEE ELEC. FOR POWER REQ. PREFABRICATED SOLDIER BRICK COURSE, PTD. METAL CANOPY PROJECT 1/2" PAST TYP. FACE OF BRICK MTL. CLAD FASCIA BEHIND CANOPY, COLOR TO MATCH STOREFRONT, REFER TO WALL SECTION B.O. CANOPY EL. 110'-2" -EX2 FREEZER/ COOLER-BEYOND FINISHED FLOOR
(ASSUMED) EL. 100'-0" 1" INSULATED GLASS IN ROWLOCK BRICK ALUM. FRAME W/ ROWLOCK BRICK COURSE COURSE FLUSH GLAZING T INSULATED GLASS IN ALUM. PTD. MTL. DOWNSPOUT, TYP. PROVIDE SLEEVE & PIPE FRAME W/ FLUSH GLAZING, TEMP. BELOW GRADE (REFER TO CIVIL FOR COLLECTION & GLAZING IN DOORS & ADJACENT ROUTING). COORD. SIZE & LOCATIONS OF DOWNSPOUTS W/ STOREFRONT PER CODE., TYP. CANOPY SUPPLIER. 1" INSULATED METAL MASONRY EXP. JOINT PANELS W/ FLUSH MASONRY EXP. JOINT -MASONRY EXP. JOINT AT INSIDE CORNER AT MASONRY OPENING GLAZING

SCALE: 1/4" = 1'-0"





PROJECT NO:

20-4047 DRAWN BY:

HWC/

8/30/2020

DATE:

OMB NEWC

VERTICAL GRAB BAR 42" MIN. GRAB BAR 🔫 TOILET PAPER DISPENSER, FURNISHED AND \_ MIRROR W/ 2" STAINLESS STEEL FRAME INSTALLED BY OWNER, TYP. REFER TO ADA REQUIREMENTS DETAIL. PROVIDE AND INSTALL \_RONDEC MTL TRIM AT TOP OF LOWER TILE, TYP. HOLD BOTTOM OF DIVIDER WALL 12" ABOVE FLOOR 2'-0"MIN. SS1 WT3 WT1 WT5 AND TILE BOTTOM

03 INTERIOR ELEVATION

SCALE: 1/2" = 1'-0"

SCALE: 1/2" = 1'-0"

1'-6"

PROVIDE AND

INSTALL RONDEC \_ MTL TRIM AT TOP OF

LOWER TILE, TYP.

3'H X 3'W MIRROR W/ 2"

STAINLESS STEEL FRAME

PROVIDE AND

RONDEC MTL

TRIM AT TOP

WT3 WT1 WT5

OF LOWER TILE, TYP.

WT3 WT1 WT5

INSTALL

02 INTERIOR ELEVATION

SCALE: 1/2" = 1'-0"


TILE TOP OF\_


Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208


INTERIOR ELEVATIONS

A2.05

8/30/2020








03 A.D.A. REQUIREMENTS


SCALE: 1/2" = 1'-0"

Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208


	DOORS					FRAN	/IES					
DOOR / ROOM	CIZE	MATERIAL	TVDE	MATERIAL	TVDE	DEDTU		DETAILS			HRDW.	DEMARKS
NO.	SIZE	MATERIAL	ITTPE	MATERIAL	TYPE	DEPTH	HEAD	JAMB	SILL	RATING	SET	REMARKS
101 VESTIBULE	3'-0" x 7'-0" x 1-3/4"	ALUM.		ALUM.	-	-	-	-	-	-	-	HARDWARE BY DOOR MANUF CLEAR ANODIZED ALUM. PUSH BAR ON PUSH SIDE OF "OUT DOOR" - REFER TO NOTES FOR ADDITIONAL HARDWARE
102 VESTIBULE	3'-0" x 7'-0" x 1-3/4"	ALUM.		ALUM.	-	-	-	-	-	-	-	HARDWARE BY DOOR MANUF CLEAR ANODIZED ALUM. PUSH BAR ON PUSH SIDE OF "IN DOOR" - REFER TO NOTES FOR ADDITIONAL HARDWARE
103 VESTIBULE	3'-0" x 7'-0" x 1-3/4"	ALUM.		ALUM.	-	-	-	-	-	-	-	HARDWARE BY DOOR MANUF CLEAR ANODIZED ALUM. PUSH BAR ON PUSH SIDE OF "OUT DOOR" - REFER TO NOTES FOR ADDITIONAL HARDWARE
104 VESTIBULE	3'-0" x 7'-0" x 1-3/4"	ALUM.		ALUM.	-	-	-	-	-	-	-	HARDWARE BY DOOR MANUF CLEAR ANODIZED ALUM. PUSH BAR ON PUSH SIDE OF "IN DOOR" - REFER TO NOTES FOR ADDITIONAL HARDWARE
105 SALES	3'-6" x 7'-0" x 1-3/4"	ALUM.		ALUM.	-	-	-	-	-	-	-	HARDWARE BY DOOR MANUF CLEAR ANODIZED ALUM. PANIC DEVICE - REFER TO NOTES FOR ADDITIONAL HARDWARE
NOT USED	-	-		-	1	-	-	-	-	-	-	-
107 DELI	3'-0" x 7'-0" CASED OPENING	ALUM.	Е	H.M.	5	-	-	-	-	-	-	ELIASON DOOR
108 DELI	3'-0" x 7'-0" CASED OPENING	ALUM.	Е	H.M.	5	-	-	-	-	-	-	ELIASON DOOR
109 OFFICE	3'-0" x 7'-0" x 1-3/4"	H.M.	В	H.M.	1	-	-	-	-	-	-	LEVER, TRILOGY LOCK, HINGES, WALL STOP
110 OFFICE CLO.	2'-0" x 7'-0" x 1-3/4"	H.M.	С	H.M.	2	-	-	-	-	-	TRILOGY	LEVER, LOCK, PICK GUARD, HINGES, WALL STOP, UNDERCUT DOOR 1"
111 ELEC. RM.	3'-0" x 7'-0" x 1-3/4"	H.M.	В	H.M.	1	-	-	-	-	-	-	PANIC DEVICE, HINGES, CLOSER INSIDE, FLOOR STOP
112 HALLWAY	3'-0" x 7'-0" x 1-3/4"	H.M.	В	H.M.	1	-	-	-	-	-	TRILOGY	LEVER, LOCK, HINGES, CLOSER INSIDE, WALL STOP, FULL HEIGHT AND WIDTH S.S DOOR PROTECTION PLATE ON PUSH SIDE
113 W. RESTROOM	2'-4" x 6'-8" x 1-3/4"	H.M.	D	H.M.	4	-	-	-	-	-	-	OCCUPIED/UNOCUPPIED DEADBOLT, PUSH/PULL DRILLED TO ACCOMMODATE DEADBOLT, HINGES
114 W. RESTROOM	3'-0" x 6'-8" x 1-3/4"	H.M.	D	H.M.	3	-	-	-	-	-	-	OCCUPIED/UNOCUPPIED DEADBOLT, PUSH/PULL DRILLED TO ACCOMMODATE DEADBOLT, (1) HINGE, (1) SPRING HINGE
115 CLOSET	3'-0" x 7'-0" x 1-3/4"	H.M.	В	H.M.	1	-	-	-	-	-	-	PASSAGE LEVER SET, HINGES, CLOSER WITH 90° STOP AND MOUNTED INSIDE CLOSET
116 M. RESTROOM	3'-0" x 6'-8" x 1-3/4"	H.M.	D	H.M.	3	-	-	-	-	-	-	OCCUPIED/UNOCUPPIED DEADBOLT, PUSH/PULL DRILLED TO ACCOMMODATE DEADBOLT, (1) HINGE, (1) SPRING HINGE
117 STORAGE	3'-0" x 7'-0" x 1-3/4"	H.M.	В	H.M.	1	-	-	-	-	-	-	PULL, CLOSER INSIDE, HINGES, CLOSER STOP AT 110°, FULL HEIGHT AND WIDTH S.S DOOR PROTECTION PLATE ON PUSH SIDE
118 STORAGE	3'-0" x 7'-0" x 1-3/4"	G.H.M.	А	G.H.M.	1A	-	-	-	-	_	-	GALV, INSUL, PANIC DEVICE (NO HARDWARE OUTSIDE), SCREW ON WEATHER STRIPPING & SWEEP, THRESHOLD, PEEP HOLE, HINGES, CLOSER, 4" HEAD
119 DISHWASHING	3'-6" x 7'-0" x 1-3/4"	G.H.M.	F	G.H.M.	6	8 1/2"	-	-	-	-	-	GALV, INSUL, PANIC DEVICE (NO HARDWARE OUTSIDE), SCREW ON WEATHER STRIPPING & SWEEP, THRESHOLD, PEEP HOLE, HINGES, CLOSER, 4" HEAD

- 1. GLASS SHALL BE TEMPERED WHERE REQUIRED BY CODE.
- 2. VERIFY ALL WALL DEPTHS, REQUIRED FRAME DEPTHS AND FRAME DIMENSIONS IN THE FIELD.
- 3. DOOR 110B SHALL HAVE A THRESHOLD, PEEPHOLE, PICK GUARD AND WEATHER STRIPPING. 4. DOORS 100A, 100B, 100C AND 100D SHALL BE KEYED ALIKE. PUSH BAR ON IN AND OUT.
- 5. DOORS 103A AND 108 SHALL BE KEYED ALIKE
- 6. DOOR 103B OFFICE CLOSET SHALL BE KEYED SEPARATELY
- 7. ALL DOORS SHALL HAVE 3 HINGES EXCEPT FOR ENTRANCE DOORS, REFER TO NOTES BELOW
- 8. ALL HINGES ARE BALL BEARING
- 9. ALL CLOSURES ARE MEDIUM DUTY
- 10. ALL LEVER SETS ARE MEDIUM DUTY
- 11. DOOR HARDWARE SHALL MEET HANDICAP REQUIREMENTS
- 12. ALL DOORS SHALL HAVE DOOR SILENCERS AND DOOR STOPS INCLUDING RESTROOM STALL DOORS.
- 13. HARDWARE FOR ALUM. DOORS 100A, 100B, 100C, 100D AND 101A PROVIDED BY MANUFACTURER. HINGES (1 ½ PAIR OF BUTT HINGES FOR DOOR 101A, CONTINUOUS HINGES FOR DOORS 100A, 100B, 100C AND 100D), DEADLOCK, WITH 5 PIN CYLINDER (KEYED ALIKE), INTERIOR THUMB TURN, GRADE 1, ADA. CLOSER, WITH ADJUSTABLE SPRING TENSION, ADA THRESHOLDS (GROUTED SOLID), WEATHER STRIP, & BOTTOM RAIL SWEEP. REFER TO SCHEDULE FOR PUSH BARS AND PANIC DEVICE. NO PULLS ON ALUM DOORS.
- 14. CLOSERS ON DOORS INTO STORAGE AND RESTROOMS SHALL BE INSTALLED ON STORAGE AND RESTROOM SIDE SO THAT THEY ARE NOT VISIBLE FROM THE HALLWAY.





# O1 DOOR DETAILS SCALE: 1/4" = 1'-0"



LOCATIONS

PARTITION DETAILS

SCALE: 3/4" = 1'-0"

PROJECT NO: 20-4047

DRAWN BY: HWC/

DATE: 8/30/2020

NEWCOMB

Keyes Architects and Associates expressly reserve its common law copyright and SCHEDULES other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or

matter whatsoever nor are they to be assigned to any third party without first

obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

A3.03

			1					
WT4	9/16" FIRED BRICK FLATS	#410 LINCOLN HERITAGE	EVOLUTION BRICK					
	WALL TILE	#543 DRIFTWOOD						
WT5	6 X 36 COLORBODY PORCELAIN TILE	#HH03 TEAK	DALTILE					
	WALL/FLOOR TILE	#145 LIGHT SMOKE						
WT6	4 X 8 GLAZED PORCELAIN TILE	CUSTOM COLOR - QTC1481P 4x8 QT01	DALTILE					
WIO	WALL TILE	#09 NATURAL GREY						
WT7	12 X 12 COLORBODY PORCELAIN TILE	#VL78 ACCEN\T BROWN	DALTILE					
VVII	COVEBASE TILE	#145 LIGHT SMOKE						
	FINISHING & EDGE-PROTECTION PROFILES	FINISH: AT SATIN NICKEL ANODIZED ALUM	SCHLUTER SYSTEMS _SCHLUTER.COM					
WT9	FOR WALLS	- DESIGNLINE 1/4"	1.800.472.4588					
	USED ON ALL HIGH ABUSE CORNERS W/TILE	- RONDEC 1/4"						
FRP-1	MARLITE AT 10'-0"	STANDARD COLOR	MARLITE					
FRF-1	WALL COVERING							
INT	ERIOR GENERAL NOTES:							
2. U	1. ROUTE ALL ELECTRICAL COMPONENTS TO DECORATIVE LIGHTING OUT OF CUSTOMER'S VIEW. 2. USE ALUMINUM KICK PLATES ON BOTH THE INSIDE AND OUTSIDE OF REST ROOM DOORS. (BY OWNER) 3. ALL FIXTURES ON DOORS TO BE USSED BUILD CUROMUM UNITESS OTHERWISE SPECIFIED.							

- 3. ALL FIXTURES ON DOORS TO BE US26D DULL CHROMIUM UNLESS OTHERWISE SPECIFIED. 4. MAIN SALES CABINET TO BE FINISHED IN (L1) ON EMPLOYEE SERVICE SIDE AND SUPPORT AREAS.
- 5. COOLER DOORS TO BE FACTORY FINISH BLACK FRAMES.
- 6. SALES FLOOR GONDOLAS TO BE FACTORY FINISHED BLACK.
- 7. ALL FLOOR TILE GROUT TO HAVE "GROUT BOOST."
- 8. EXPOSED DUCTWORK MUST BE PRIMED AND PAINTED BEFORE CEILING IS PAINTED. 9. CONTRACTOR SHALL CAULK DOOR JAMBS INSIDE RESTROOMS WITH SANDED CAULK PROVIDED BY LOUISVILLE TILE. ALL OTHER DOOR JAMBS AND MARLITE TO
- BE CAULKED WITH SHERWIN WILLIAMS POWER HOUSE 60 YR, COLOR: TO MATCH GROUT
- 10. ALL GYPBD WALLS SHALL BE PAINTED. 11. PAINT EXPOSED STRUCTURE
- 12. PROVIDE AND INSTALL RONDEC MTL TRIM AT ALL OUTSIDE TILE CORNERS AND WHERE NOTED ON INTERIOR ELEVATIONS.
- 13. "GROUT BOOST" TO BE USED TO MIX GROUT INSTEAD OF WATER.
- 14. ALL EXTERIOR BOLLARDS SHALL BE PAINTED BY NEWCOMB OIL CO 15. INSTALL WHITE CAULK AT ALL WALL TO CEILING JOINTS
- 16. TOP OF "WT5" TILE SHALL BE APPROXIMATELY 41" ABOVE FINISH FLOOR TO PREVENT THIN CUT TILE AT FLOOR AND CEILING. THE 41" DIMENSION CAN BE ADJUSTED SLIGHTLY TO ACHIEVE NO LESS THAN HALF A TILE AT THE FLOOR AND CEILING.

## GRAPHIC DETAIL NOTES (GRAPHICS BY OWNER)

CODE	DESCRIPTION - REFER TO INTERIOR RENDERINGS FOR OVERALL GRAPHIC APPEARANCE.
CODE	CONTACT PARAGON FOR ORIGINAL ARTWORK.
1D	"FIVE STAR" SIGN: THE TEXT IS TO BE 1" DIMENSIONAL TEXT & BACKLIT IN WHITE LED HALO LIGHTING.
טו	THE TEXT IS TO BE PAINTED ON ALL SIDES.
3D	"COFFEE BREW" SIGN/GRAPHIC: THE BACKGROUND CIRCLE IS TO BE HUNG FROM THE CEILING BY A CHAIN LINK.
	THE "COFFEE BREW" TEXT IS TO BE BACKLIT IN RED LED HALO. THE CUP IS TO BE 3D AND PROTRUDING FROM THE CIRCLE.
4D	"FREEZE & FOUNTAIN" SIGN: THE BACKGROUND BAND IS TO BE A BRUSHED STAINLESS STEEL METAL.
15	THE "FREEZE & FOUNTAIN" TEXT ARE TO BE BACKLIT IN BLUE LED HALO LIGHTING.
5D	"RESTROOM", "MENS", & "WOMENS" SIGNS: THE "RESTROOM" TEXT IS TO BE 1/2" THICK DIMENSIONAL & PAINTED ON ALL SIDES.
	THE MENS & WOMENS TEXT IS TO BE 1/4" THICK DIMENSIONAL AND FACED IN A BRUSHED STAINLESS STEEL LAMINATE.
6D	"GET THE FIVE STAR TREATMENT EVERY TIME" SIGN: THE TEXT IS TO BE 2" THICK DIMENSIONAL TEXT AND PAINTED ON
-	ALL SIDES. THE LETTERS ARE TO BE BACKLIT IN YELLOW LED HALO LIGHTING.
7D	"ATM" SIGN: THE TEXT IS TO BE 1/2" THICK DIMENSIONAL TEXT AND OUTLINED IN BRUSHED STAINLESS STEEL.
	NOTE: NOT IN ELEVATIONS - TO BE PROVIDED AS NECESSARY. BY OWNER.
	"THE BEER CAVE" SIGN/GRAPHIC: THE BACKGROUND OVAL IS TO BE MADE OF BRUSHED STAINLESS STEEL (OR ALUMINUM).
8D	"THE BEER CAVE" TEXT IS TO BE 2" THICK DIMENSIONAL TEXT AND PAINTED ON ALL SIDES.
OD	THE 3 SNOW FLAKES ARE TO BE AT 3 DIFFERENT DEPTHS AND THE ARE TO HAVE BLUE LED HALO LIGHTING PLACED BEHIND
	EACH INDIVIDUAL CIRCLE.
9D	ICE WALL GRAPHIC: IS TO BE A DIGITALLY PRINTED WALL GRAPHIC WRAP TO BE APPLIED TO THE INTERIOR WALLS OF THE
	BEER CAVE. MAKE SURE ALL ASSEMBLY ELEMENTS ARE ADAPTABLE FOR CONSTANT COLD TEMPERATURES.

### **GRAPHIC GENERAL NOTES**

- DETERMINE ALL GRAPHIC APPLICATIONS BY USING FIELD DIMENSIONS ONLY.
- NO GRAPHIC SUBSTITUTIONS ARE ALLOWED WITHOUT PARAGON SOLUTIONS OR OWNERS CONSENT.
- REVIEW ALL FINAL PRODUCTION DRAWINGS WITH PARAGON SOLUTIONS PRIOR TO PRODUCTION.


4. PROVIDE INSTALLATION COSTS UNLESS OTHERWISE NOTED.

PROJECT NO:


20-4047

DRAWN BY: HWC/ DATE: 8/30/2020

Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208



Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered proprietary information and shall not be upgraded, changed or copied in any form or matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208





BUILDING SECTIONS & DETAILS


matter whatsoever nor are they to be assigned to any third party without first


obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208

A5.02









02 FLOOR SINK SECTION

SCALE: 1-1/2" = 1'-0"


20-4047 DRAWN BY: HWC/ DATE:


PROJECT NO:


8/30/2020

Keyes Architects and Associates expressly reserve its common law copyright and other property rights in these documents. These documents are considered DETAILS proprietary information and shall not be upgraded, changed or copied in any form or

matter whatsoever nor are they to be assigned to any third party without first obtaining the express written permission and consent of Keyes Architects and Associates, 3005 Taylor Boulevard, Louisville, Kentucky 40208







**A5.08** 

RANGE HOOD						
SYMBOL	RH-1					
MANUFACTURER	CAPTIVEAIRE					
MODEL	4224EX-2-B					
SERVICE	DELI AREA					
PHYSICAL SIZE	111"L X 42"D					
INTEGRAL FIRE SUPPRESSION	NO					
MOUNTING HEIGHT	6'-8" AFF					
TYPE	TYPE 1					
EXHAUST F	AN					
MARK	EF-1					
MANUFACTURER AND MODEL #	CAPTIVEAIRE — DU85HFA					
EXHAUST CFM/ESP	1850 / 1.0"					
ELECTRICAL (V/ø/HZ)	115 / 1 / 60					
FAN HP/RPM	1 HP / 1359					
FLA	10.2					
WEATHER PROOF DISCONNECT	YES					
GREASE DRAIN	YES					

### <u>REMARKS:</u>

SYMBOL

S-1

S-2

S-3

S-4

S-5

R-1

R-2

R-3

<u>REMARKS</u>

- RANGE HOOD IS OWNER FURNISHED, OWNER INSTALLED. 2. PROVIDE THE HOOD IN ONE SECTION. ATTACH UNIT TO WALL WITH MANUFACTURER'S WALL BRACKET. COORDINATE MOUNTING LOCATION WITH THE ARCHITECT. 3. ALL COMPONENTS OF THE RANGE HOOD SHALL BE UL LISTED
- 4. UNIT TO BE PROVIDED WITH ELECTRIC RELAY SWITCH BOX FOR ELECTRIC RANGE. COORDINATE INSTALLATION WITH THE ELECTRICAL CONTRACTOR. 5. PROVIDE EXHAUST FAN WITH GREASE BOX, GREASE CUP, AND
- MANUFACTURER'S ROOF CURB. PROVIDE HOOD WITH LED LIGHT FIXTURES.
- INFORMATION IS PROVIDED FOR COORDINATION PURPOSES. 8. FAN IS TO BE UL LISTED FOR KITCHEN USE AND GREASE LADEN
- 9. PROVIDE HOOD WITH 24" FIELD WRAPPER.
- 10. FAN AND LIGHT CONTROLS ARE TO BE MOUNTED ON FRONT OF HOOD, EACH SWITCH SHALL HAVE AN INDICATOR LIGHT AND IDENTIFICATION PLACARD. COORDINATE EXACT LOCATION WITH OWNER. 11. THE FIRE SUPPRESSION SYSTEM SHALL BE THE PRE-ENGINEERED
- TYPE WITH A FIXED NOZZLE AGENT DISTRIBUTION NETWORK. IT SHALL BE UL LISTED AND INSTALLED PER MANUFACTURER'S RECOMMENDATIONS. 12. THE SYSTEM SHALL BE CAPABLE OF AUTOMATIC DETECTION AND ACTUATION WITH LOCAL OR REMOTE MANUAL ACTUATION.
- ACCESSORIES SHALL BE AVAILABLE FOR MECHANICAL OR ELECTRICAL GAS LINE SHUT-OFF APPLICATIONS. 13. THE EXTINGUISHING AGENT SHALL BE A POTASSIUM CARBONATE, POTASSIUM ACETATE-BASED FORMULATION DESIGNED FOR FLAME KNOCKDOWN AND SECUREMENT OF GREASE RELATED FIRES. IT SHALL
- BE AVAILABLE IN PLASTIC CONTAINERS WITH INSTRUCTIONS FOR LIQUID AGENT HANDLING AND USAGE. 14. THE REGULATED RELEASE MECHANISM SHALL BE COMPATIBLE WITH A FUSIBLE LINK DETECTION SYSTEM. THE FUSIBLE LINK SHALL BE SELECTED AND INSTALLED ACCORDING TO THE OPERATING TEMPERATURE IN THE VENTILATING SYSTEM. THE FUSIBLE LINK SHALL
- BE SUPPORTED BY A DETECTOR BRACKET/LINKAGE ASSEMBLY. 15. BALANCING CONTRACTOR TO BALANCE EXHAUST FAN TO WITHIN 5% OF LISTED AIRFLOW.

MANUF. & MODEL

TITUS

TMRA

TITUS

TMRA

TITUS

TMRA

TITUS

TMSA

TITUS

300RS

TITUS

TITUS

23RL

TITUS

355RL

PROVIDE WHITE IN COLOR.

CEILING SURFACE MOUNTED.

HART & COOLEY

INLET TRANSITION BOX, ROUND TO RECTANGULAR.

GRILLE SHALL BE SIDEWALL/DUCT MOUNTED.

PROVIDE WITH MOLDED INSULATION BLANKET ON DIFFUSER.

PROVIDE DESIGNATED TYPE "B" DIFFUSERS WITH 3-WAY THROW.

350ZRL

MAKE-UP AIR UNIT						
GENERAL INFORMATION						
SYMBOL	MAU-1					
MANUFACTURER	CAPTIVEAIRE					
MODEL	A1-D.250-G10-MPU					
CFM / ESP	1665 / 0.45"					
HP / RPM	1 HP / 1073					
V/ø/HZ	115 / 1 / 60					
FLA	9.0					
INPUT (GAS)	109.6 MBH					
TEMP. RISE	59° F					
WEIGHT	1250 LBS					
CONDENSING UNIT INFORMATION						
V/ø/HZ	208 / 1 / 60					
MCA / MOP	18.1 / 30					
TOTAL / SENSIBLE CAPACITY (MBH)	31.4 / 20.9					
ENTERING AIR DB / WB	88.0° F / 73.0° F					
LEAVING AIR DB / WB	75.7° F / 67.7° F					

### **REMARKS**:

REGISTERS, GRILLES, AND DIFFUSERS

CFM RANGE

0-130

131-250

251-375

0-100

0-450

3000

0-100

0-100

MATERIAL & TYPE

STEEL CONSTRUCTION

STEEL CONSTRUCTION

STEEL CONSTRUCTION

STEEL CONSTRUCTION

EXTRUDED ALUMINUM

DOUBLE DEFLECTION

STEEL LOUVERED GRILLE 3/4" BLADE SPACING 0' DEFLECTION

STEEL RETURN GRILLE

45° DEFLECTION 3/4" BLADE SPACING

STEEL LOUVERED GRILLE 1/2" BLADE SPACING 35° DEFLECTION

ALUMINUM CONSTRUCTION "Y" TYPE BLADE

VISION PROOF

PROVIDE WITH PLENUM BOX. PAINT INTERIOR OF PLENUM BOX WITH FLAT BLACK PAINT.

3 CONE 360° PATTERN

3/4" SPACING

360° UNIFORM PATTERN

360° UNIFORM PATTERN

360° UNIFORM PATTERN

- ALL COMPONENTS OF THE MAKEUP AIR UNIT SHALL BE UL LISTED. PROVIDE UNIT WITH COOLING INTERLOCK RELAY.
- PROVIDE WITH LOW-FIRE START.
- THIS UNIT HAS TWO POWER CONNECTIONS.
- PROVIDE WITH DX COOLING INTAKE AIR THERMOSTAT AND RELAYS MOUNTED IN
- 6. PROVIDE MAKEUP AIR UNIT WITH FACTORY MOUNTED AND WIRED CONTROL PANEL. PANEL SHALL CONTAIN (1) POWER DISCONNECT SWITCH AND (1) STARTER FOR SUPPLY FAN AND (1) STARTER FOR THE EXHAUST FAN. PANEL SHALL BE PRE-WIRED IN A NEMA OUTDOOR ENCLOSURE WITH STAINLESS STEEL HINGED AND LOCKABLE COVER.
- PROVIDE A FULL PERIMETER ROOF CURB FOR MAKE-UP AIR UNIT. PROVIDE WITH MOTORIZED BACKDRAFT DAMPER IN INTAKE OF UNIT

SIZE

6"ø

8**"**ø

10**"**ø

6**"**ø

12"x10"

12x10"

46"x46"

10"x8"

10"x10"

FACE SIZE

20"ø

22.5**"**ø

22.5**"**ø

12"x12"

14"x12"

14"x12"

48"x48"

12"x10"

12"x12"

DUCT SIZE

6''ø

8**"**ø

10**"**ø

12"x10"

12"x10"

46"x46"

10"x8"

10"x10"

- INTERLOCKED TO OPEN WITH SUPPLY FAN. DAMPER SHALL HAVE SEALS. PROVIDE A REMOTE RANGEHOOD CONTROL PANEL WHERE INDICATED ON THE NEW WORK DRAWINGS. PANEL SHALL HAVE TWO (2) SWITCHES; (1) ACTIVATE SUPPLY AND EXHAUST FAN, (2) ACTIVATE HOOD LIGHTS, EACH SWITCH SHALL HAVE AN INDICATOR LIGHT AND IDENTIFICATION PLACARD.
- 10. PROVIDE WITH MODULATING GAS VALVE. BALANCING CONTRACTOR TO BALANCE MAU TO WITHIN 5% OF LISTED AIRFLOW.

### <u>REMARKS:</u>

REMARKS

1, 2, 3, 5, 7

3, 5, 6

EFFICIENCY

SIZE (W" x H" x D")

AREA SERVED

TYPE OF SYSTEM

MANF. & MODEL

CONFIGURATION

VOLTAGE / PHASE

DESIGN CFM/RPM

HP / BHP

TOTAL CFM

EER @ AHRI

CAPACITY

LAT (DB)

FACE VELOCITY (FPM)

NUMBER OF COMPRESSORS EAT - SUMMER (DB/WB)

LAT - SUMMER (DB/WB)

MIN. OUTSIDE AIR (CFM)

VOLTS / PHASE / HZ

NET TOTAL COOLING CAP. (MBH)

NET SENSIBLE COOLING CAP. (MBH)

COIL MOISTURE REMOVAL (LB/HR)

INPUT / OUTPUT HEATING CAP. (MBH)

EAT - WINTER (DB/WB)

LAT – WINTER (DB/WB)

MCA / MOP

SINGLE POINT CONNECTION

REMARKS (SEE NOTES BELOW)

PROVIDE FLEXIBLE CONNECTIONS FOR ALL DUCTWORK AND PIPING CONNECTIONS TO UNIT. SLOPE CONDENSATE DRAIN TO OUTLET.

PACKAGED COOLING UNIT

SUPPLY FAN

DX COIL

HOT GAS REHEAT CAPACITY

GAS HEATING

DISPOSABLE PRIMARY FILTER

GENERAL

TRANE YHC120

HORIZONTAL

208 / 3ø

46.1 / 60.0

4000 / 1552

3.18 / 3.18

208 / 3 / 60

575

1.0"

1.46"

99.4

83.1

4000

240

12.4

89.1

17.9

75.2 F

NATURAL GAS

70.0 F

98.1 F

THROWAWAY

20x25x2

MERV 7 PLEATED

150.0 / 120.0

76.0 F / 63.0 F

57.2 F / 54.3 F

YES

DX COOLING / GAS HEAT

- PROVIDE WITH HIGH EFFICIENCY FAN MOTORS. PROVIDE ALL UNITS WITH A SINGLE POINT CONNECTION, AND FACTORY INSTALLED
- STARTERS AND NON-FUSIBLE DISCONNECTS. PROVIDE WITH HONEYWELL MODEL TH8321R1001 REDLINK PROGRAMMABLE THERMOSTAT, HONEYWELL MODEL C7189R1004 REDLINK REMOTE TEMPERATURE SENSORS, AND HONEYWELL MODEL THM6000R1002 REDLINK INTERNET GATEWAY.
- PROVIDE UNIT WITH HAIL GUARD.
- PROVIDE WITH A 120V SERVICE OUTLET. PROVIDE WITH 14" TALL FACTORY MOUNTED SHEET METAL CURB. CURB SHALL NOT EXTEND BEYOND UNIT.
- MOTORIZED OUTSIDE AIR DAMPER. (BALANCE MINIMUM OA TO 575 CFM.) PROVIDE UNIT WITH ENTHALPY ECONOMIZER AND ECONOMIZER HOOD.
- PROVIDE UNIT WITH HINGED ACCESS DOORS FOR FILTER RACK.
- BALANCE REPORT SHALL BE TURNED OVER TO GENERAL CONTRACTOR. UNIT MANUFACTURER SHALL BE TRANE, NO EXCEPTIONS.
- PROVIDE REMOTE MOUNTED BARAMETRIC RELIEF HOOD. HOOD SHALL BE MOUNTED ON RETURN DUCT. REFER TO MECHANICAL DRAWINGS FOR LOCATION.
- 15. UNIT SHALL HAVE RETURN AIR DUCT SMOKE DETECTOR. INSTALL UPSTREAM OF BARAMETRIC RELIEF HOOD.
- 16. PROVIDE UNIT WITH HOT GAS REHEAT FOR DEHUMIDIFICATION MODE AND DUCT-MOUNTED
- HUMIDISTAT SET AT 50% RELATIVE HUMIDITY. 17. PROVIDE UNIT WITH MULTI-SPEED SUPPLY FAN STAGED WITH COMPRESSORS.

Mate	erial Re	equir	emen	ts to Ach	ieve Instal	led R-V	alue			
	minal kness		talled kness	Stretch Out Dimensions, in. (mm)						
in.	(mm)	in.	(mm)	Round and	Oval Ducts	Square	Ducts	Rectangu	lar Ducts	
11/2	(38)	11/8	(29)	P+9 <sup>1</sup> / <sub>2</sub>	(240)	P+8	(205)	P+7	(180)	
2	(51)	1½	(38)	P+12	(305)	P+10	(255)	P+8	(205)	
21/5	(56)	15/8	(41)	P+13	(330)	P+II	(280)	P+8 <sup>1</sup> / <sub>2</sub>	(215)	
3	(76)	21/4	(57)	P+17	(430)	P+14 <sup>1</sup> / <sub>2</sub>	(370)	P+11 <sup>1</sup> / <sub>2</sub>	(290)	
4	(102)	3	(76)	P+22	(560)	P+19	(483)	P+16	(406)	
P = mea	sured duct	perimet	ter							

r – measured duct perimeter
SEAM  BUTT JOINT  DO NOT COMPRESS WRAP EXCESSIVELY AT CORNERS  TAPE FLAP  TAPE FLAP  THIS  NOT THIS  NOT THIS  DO NOT COMPRESS WRAP EXCESSIVELY AT CORNERS
All seams and joints stapled approximately 6" (150mm) on centers before sealing with tape or mastic.

# **EXHAUST FAN**

SYMBOL	EF-2	EF-3
MANUFACTURER	соок	соок
MODEL	GC-182	GC-162
CFM	225	150
S.P.	0.25"	0.25"
VOLTAGE	115/1/60	115/1/60
WATTS	169	96

### **REMARKS:**

- UNIT TO BE SUPPLIED WITH A BACKDRAFT DAMPER AND ALUMINUM EXTERIOR WALL CAP WITH BIRDSCREEN.
- UNIT TO BE PROVIDED WITH SPEED CONTROLLER.


### MECHANICAL LEGEND

AFF	ABOVE FINISHED FLOOR
TYP	TYPICAL
NTS	NOT TO SCALE
NIC	NOT IN CONTRACT
NO	NORMALLY OPEN
NC	NORMALLY CLOSED
	TAGGED NOTE
	INDICATES AIR DISTRIBUTION DEVICE SPECIFICATION (L=LOUVER, T=TRANSFER GRILLE, S=SUPPLY DIFFSER OR REGISTER, R=RETURN GRILLE OR REGISTER, E= EXHAUST GRILLE OR REGISTER)
	MECHANICAL EQUIPMENT DESIGNATOR
20X12 SA 🔀	SUPPLY AIR DUCT - INSIDE DIMENSION (TURNED UP/DOWN)
20X12 RA	RETURN AIR DUCT — INSIDE DIMENSION (TURNED UP/DOWN)
20X12 EA	EXHAUST/RELIEF AIR DUCT - INSIDE DIMENSION (TURNED UP/DOWN)
811111118	FLEXIBLE DUCT
[] AD	ACCESS DOOR IN BOTTOM OF DUCT
AD	ACCESS DOOR IN SIDE OF DUCT
<u> </u>	OPPOSED BLADE DAMPER (MOTORIZED)
	VOLUME DAMPER (MANUAL)
	TURNING VANES
$T_s$	TEMPERATURE SENSOR

### GENERAL NOTES (APPLICABLE TO ALL DRAWINGS)

- A. EACH CONTRACTOR, SUPPLIER AND, OR MANUFACTURER SHALL REFER TO ALL DOCUMENTS PERTAINING TO THIS PROJECT AND COORDINATE ACCORDINGLY SO AS TO ENSURE ADEQUACY OF FIT, COMPLIANCE WITH SPECIFICATIONS, PROPER VOLTAGE AND CURRENT CHARACTERISTICS AND AVOID CONFLICT WITH ANY OTHER BUILDINGS SYSTEMS. VERIFY SAME WITH SHOP DRAWINGS.
- B. ALL OFFSETS, TURNS, FITTINGS, TRIM, DETAIL, ETC., MAY NOT BE INDICATED, BUT SHALL BE PROVIDED AS REQUIRED. ADDITIONAL ALLOWANCES SHALL BE INCLUDED FOR SAME AT EACH PROPOSERS' DISCRETION.
- OBSERVE ALL APPLICABLE CODES, RULES AND REGULATIONS (CITY, COUNTY, LOCAL, STATE, FEDERAL, MUNICIPALITY, UTILITY COMPANY, OSHA, ETC.).
- ALL SYSTEMS, EQUIPMENT, AND MATERIALS ARE TO BE INSTALLED IN A NEAT AND WORKMANLIKE MANNER. WORK NOT DONE SO SHALL BE REMOVED AND REINSTALLED SATISFACTORILY.
- WHERE MOUNTING HEIGHTS ARE NOT INDICATED OR ARE IN CONFLICT WITH ANY OTHER BUILDING SYSTEM, CONTACT THE ENGINEERS BEFORE INSTALLATION. REFER ALSO TO ARCHITECTURAL WALL INTERIOR AND EXTERIOR WALL ELEVATIONS, CEILING HEIGHTS AND OTHER DETAIL OF THESE DOCUMENTS.
- F. DO NOT SCALE FROM DRAWINGS, PRINTING DISTORTS SCALE. WORK SHALL BE LAID OUT FROM DIMENSIONED DRAWINGS, OR DIMENSIONS SUPPLIED TO THE CONTRACTOR.
- G. THE PURPOSE AND INTENT OF ALL THE DOCUMENTS PERTAINING TO THIS PROJECT IS TO PROVIDE A COMPLETE, FUNCTIONAL, SAFE, NEW FACILITY. ANYTHING LESS SHALL BE UNACCEPTABLE.
- H. ANY VIBRATING, OSCILLATING, OR OTHER NOISE OR MOTION PRODUCING EQUIPMENT SHALL BE ISOLATED FROM SURROUNDING SYSTEMS IN AN APPROVED MANNER. NOISY OR STRUCTURALLY DAMAGING INSTALLATIONS SHALL BE SATISFACTORILY REPLACED OR REPAIRED AT THE INSTALLING CONTRACTOR'S EXPENSE. THE FINAL DECISION ON THE SUITABILITY OF A PARTICULAR INSTALLATION'S ACCEPTABILITY SHALL BE THAT OF THE ENGINEER.
- INSTALL EQUIPMENT, MATERIALS, ETC. IN STRICT ACCORD WITH MANUFACTURER'S RECOMMENDATIONS AND DIRECTIONS. IF IN CONFLICT WITH THE DESIGN INDICATED IN CONTRACT DOCUMENTS. NOTIFY THE ENGINEERS PRIOR TO INSTALLATION FOR CLARIFICATION.

- J. ALL SUPPORTS FOR EQUIPMENT, DEVICES OR FIXTURES SHALL BE UNIQUE, FROM THE BUILDING STRUCTURE. DO NOT SUPPORT WORK FROM OTHER TRADES, EQUIPMENT, OR SUPPORTS WITHOUT WRITTEN PERMISSION FROM THE ENGINEER AND CONSENT OF THE OTHER TRADE. IN WRITING.
- FROM THAT PRIME SPECIFIED SHALL BE THE RESPONSIBILITY OF THE PURCHASER OF THAT EQUIPMENT. ANY PROVISIONS REQUIRED TO ACCOMMODATE A DEVIATION, WHETHER APPROVED BY THE ENGINEERS OR NOT, SHALL BE THE RESPONSIBILITY OF THE PURCHASER. L. THE GENERAL CONTRACTOR FOR THIS CONSTRUCTION IS RESPONSIBLE
- FOR THE COORDINATION, APPEARANCE, SCHEDULING, AND TIMELINESS OF THE WORK OF ALL TRADES, CONTRACTORS, SUPPLIERS, INSTALLERS, ETC.
- SHALL NOT BE LOCATED ABOVE A HARD CEILING. IF THIS IS NOT POSSIBLE, THEN AN APPROPRIATELY SIZED ACCESS DOOR SHALL BE PLACED UNDER THE ITEM TO ALLOW EASY MAINTENANCE AND
- BETWEEN ALL TRADES SUCH THAT CONDUITS, PIPING, DUCTWORK, ETC. DO NOT BLOCK ACCESS TO VALVES, EQUIPMENT, DUCT ACCESS DOORS, ETC. ITEMS THAT HAVE BEEN INSTALLED WHERE ACCESS IS
- P. THE EQUIPMENT ROUGH-IN ITEMS AND THEIR DIMENSIONED LOCATIONS FOR ALL CONNECTIONS ARE ACCURATE TO THE BEST OF OUR KNOWLEDGE AND SHALL BE VERIFIED WITH THE EQUIPMENT SUPPLIER, OWNER AND/OR THE EQUIPMENT ROUGH-IN DRAWINGS. IN SOME INSTANCES, THE OWNER OR SUPPLIER MAY MAKE SUBSTITUTIONS OR THE EQUIPMENT ITEM MAY VARY FROM WHAT IS SHOWN. THEREFORE, THE ARCHITECT/ENGINEER SHALL BE IMMEDIATELY NOTIFIED, PRIOR TO CONSTRUCTION OF ANY DEVIATIONS FROM WHAT IS SHOWN OR IMPLIED ON THESE DRAWINGS. FAILURE OF THE APPROPRIATE CONTRACTOR TO VERIFY ROUGH-INS OR THEIR LOCATIONS SHALL PLACE RESPONSIBILITY FOR ANY SUBSEQUENT RELOCATION AND/OR ADDITIONAL ROUGH-INS DIRECTLY UPON THE CONTRACTOR.



REMOTE TEMPERATURE SETPOINT CONTROLLER

DUCT SMOKE DETECTOR

K. DEVIATIONS IN SIZE, CAPACITIES, FIT, FINISH, ETC. FOR EQUIPMENT

- M. VALVES, BALANCING DAMPERS, OR ANY MECHANICAL/ELECTRICAL ITEM
- N. THE GENERAL CONTRACTOR SHALL ENSURE PROPER COORDINATION COMPROMISED SHALL BE RELOCATED AT THE CONTRACTOR'S EXPENSE.
- O. REFER TO DETAIL SHEETS FOR ADDITIONAL PIPING/DUCTWORK INSTALLATION REQUIREMENTS.

MECHANICAL LEGEND AND SCHEDULES

M1.01



PROJECT NO: 20-4047 DRAWN BY:

WTD

DATE:

8/30/2020

- A. ALL OPEN-CEILING AREAS SHALL UTILIZE A RIGID DUCT CONNECTION (WITH SUPPORTS) TO DIFFUSER. DIFFUSER SHALL BE MOUNTED AT A TYPICAL ELEVATION OF 11'-0" UNLESS OTHERWISE SHOWN ON DRAWING. TYPICAL PLACEMENT OF DIFFUSER IN OPEN-CEILING AREAS ARE CENTERED BETWEEN JOISTS UNLESS SPECIFIC DIMENSION IS SHOWN ON DRAWING.
- B. ALL RECTANGULAR, ROUND, AND FLEXIBLE DUCTS SHALL BE SIZED AS SHOWN ON THESE DRAWINGS. MINIMUM INTERNAL DIMENSIONS ARE GIVEN.
- C. INSTALL TURNING VANES IN ALL 90 DEGREE SUPPLY AND RETURN DUCT ELBOWS AND AT ALL DUCT TEES.
- D. CONDENSATE DRAIN LINES SHALL BE SLOPED AT A MINIMUM 1/8" PER LINEAR FOOT OF RUN. ALL DRAIN EXITS FROM PCU-1 SHALL INCLUDE A TRAP AND CLEAN-OUT PLUG.

ALL PIPING VALVES AND MANUAL VOLUME DAMPERS SHALL BE EASILY ACCESSIBLE.

- E. CONTRACTOR SHALL HAVE ALL THERMOSTATS/TEMPERATURE SENSORS CALIBRATED TO MANUFACTURER'S SPECIFICATIONS PRIOR TO TURNING SYSTEM OVER TO OWNER.
- BALANCE DIFFUSERS AND GRILLES TO AIRFLOWS INDICATED ON PLAN. PROVIDE AIR-BALANCE REPORT TO GENERAL CONTRACTOR.
- G. MANUFACTURER'S RECOMMENDED CLEARANCES SHALL BE MAINTAINED FOR ALL MECHANICAL EQUIPMENT.
- H. FLEXIBLE DUCTWORK IS ALLOWED FOR USE ON CONCEALED DUCTWORK. REFER TO DETAIL SHEET FOR MORE INFORMATION.
- HATCHED PORTION OF DUCTWORK SHALL BE WRAPPED WITH OWENS/CORNING ALL SERVICE FIBERGLASS DUCT WRAP, "FACED DUCT WRAP — TYPE 75", 3" THICK FIBERGLASS DUCT WRAP, WITH A MINIMUM R-VALUE OF 8, FACTORY LAMINATED TO A REINFORCED FOIL KRAFT VAPOR BARRIER. REFER TO INSULATION CHART ON SHEET M1.01 FOR INSTALLATION REQUIREMENTS.
- ANY ROUND DUCTWORK EXPOSED TO VIEW SHALL HAVE SPIRAL OUTER SHELL, LOCK-SEAM CONSTRUCTION FABRICATED FROM PAINT GRIP GALVANIZED STEEL MEETING ASTM-527 STANDARDS. ANY DUCTWORK EXPOSED TO VIEW SHALL BE CONSTRUCTED OF G90 GALVANIZED STEEL AND SHALL BE SUPPORTED AS REQUIRED WITH AIRCRAFT CABLES WITH SELF-TIGHTENING LOCKS. EXPOSED METAL DUCT SHALL BE PREPPED AND PAINTED BY OWNER.
- DUCTWORK, PLENUMS AND OTHER APPURTENANCES SHALL BE CONSTRUCTED OF THE MATERIALS OF THE MINIMUM WEIGHTS OR GAUGES AS REQUIRED BY THE LATEST SMACNA 2" W.G. STANDARD OR BELOW TABLE. WHEN GAUGE THICKNESS DIFFERS, THE HEAVIER GAUGE SHALL BE SELECTED. THE BELOW TABLE SHALL SERVE AS A MINIMUM.

ROUND DIAMETER	R DUCT GAUGE	RECTANGULAR WIDTH	DUCT GAUGE
3-12 INCHES 13-18 INCHES 19-28 INCHES	26 GA. 24 GA. 22 GA.	3-12 INCHES 13-30 INCHES 31-54 INCHES	26 GA. 24 GA. 22 GA.

### **MECHANICAL TAG NOTES:**

- ORIENT RETURN GRILLE SO THAT OPENING IS DIRECTED TOWARD HALLWAY ENTRY (AWAY FROM BATHROOMS). PAINT INTERIOR OF RETURN PLENUM WITH FLAT BLACK PAINT.
- NON-INSULATED PVC CONDENSATE LINE. PROVIDE SPLIT RING CLAMP EVERY 4'-0" ON CENTER AND CHANGE OF DIRECTION.
- PROVIDE HIGH EFFICIENCY TAKEOFFS AND VOLUME DAMPERS IN ALL BRANCH DUCT WORK. REFER TO DETAIL ON SHEET M3.01 FOR ADDITIONAL INFORMATION. TYPICAL OF ALL.
- INSTALL RETURN DUCTWORK AS HIGH AS POSSIBLE, HOLDING TIGHT TO STRUCTURE. BOTTOM OF DUCT WILL BE AT A MINIMUM OF 9'-0".
- 5. PROVIDE FLEX CONNECTION AT UNIT FOR SUPPLY/RETURN DUCTWORK.
- 6. CONTRACTOR TO INSTALL A 20 GAUGE RAIN SHIELD OVER ALL EXTERIOR DUCTWORK. PROVIDE WITH 16"Wx32"H ACCESS DOOR FOR DUCT MOUNTED SMOKE DETECTOR. POSITION DOOR AS CLOSE TO UNIT AS POSSIBLE. REFER TO SECTION VIEW ON SHEET M3.01 FOR ADDITIONAL INFORMATION.
- PROVIDE UNIT WITH 14" TALL, FULL-LENGTH EQUIPMENT CURB. DO NOT EXTEND CURB PAST UNIT. CONCRETE PAD WILL BE SLOPED 1/4" PER FOOT.
- 8. CONTRACTOR TO INSTALL A 2" OPEN RECEPTACLE IN STORM LINE. SPILL PCU-1 CONDENSATE TO OPEN RECEPTACLE. COORDINATE INSTALLATION WITH BUILDING CONTRACTOR.
- 9. SUPPLY DUCT MAIN SHALL BE INSTALLED TO FOLLOW SLOPE OF ROOF WITHIN JOIST SPACE. ALL BRANCH DUCTWORK SHALL BE COORDINATED WITH JOIST OPENINGS.
- 10. TRANSITION FROM A 18x30 SA DUCT TO 24" AND FROM A 18x30 RA DUCT TO 24x22 WITHIN CHASE.
- REFER TO SECTION VIEW ON SHEET M3.01 FOR ADDITIONAL INFORMATION. 11. MOUNT FIRE SUPPRESSION SYSTEM FOR RH-1 AS HIGH AS POSSIBLE. SEE SHEET M1.01 FOR MORE
- INFORMATION.
- 12. SPACE IN THIS AREA IS LIMITED. COORDINATE DUCT ROUTING WITH CEILING AND STRUCTURAL JOISTS.
- 13. INSTALL ECCENTRIC TRANSITION DUCT FITTING. SLOPE OF TRANSITION IS NOT TO EXCEED 1:4.
- 14. CEILING FANS, STRUCTURAL JOISTS, AND LIGHTS ARE SHOWN FOR COORDINATION PURPOSES ONLY. (TYPICAL)
- 15. TRANSFER AIR GRILLES CENTERED ABOVE DOOR. REFER TO DETAIL SHEET.
- 16. INSTALL PCU-1 THERMOSTAT IN LOCATION SHOWN CENTERED BETWEEN CLOSET DOOR JAMB AND EDGE OF DRYWALL. INSTALL AT 60" AFF. THERMOSTAT NEEDS TO CONTROL HOT GAS REHEAT ON THE HVAC UNIT. DO SO BY CONNECTING U1 AND U1 ON THE THERMOSTAT IN THE GENERAL MANAGER'S OFFICE TO TERMINAL 7 AND 12 ON THE LTB BOARD LOCATED ON THE HVAC UNIT.
- 17. EXHAUST CAP AT ELEVATION OF 10'-8". REFER TO DETAIL SHEET FOR MORE INFORMATION.
- 18. INSTALL PCU-1 TEMPERATURE SENSOR IN LOCATION SHOWN. COORDINATE ELEVATION WITH OWNER PRIOR TO INSTALLATION.
- 19. MAINTAIN A 10'-0" MINIMUM DISTANCE FROM EXHAUST FAN OUTLET TO PCU-1/MAU-1'S INTAKE. ANY ROOF EQUIPMENT MUST MAINTAIN A 10'-0" MINIMUM DISTANCE BETWEEN EQUIPMENT AND EDGE OF ROOF.
- 20. TRANSITION GREASE DUCT FROM RH-1 HOOD OPENING TO 14" RISER. TRANSITION DUCTWORK TO FIT ROOF CURB PRIOR TO ROOF PENETRATION. ROOF CUTOUT SHALL BE 21"X21" FOR CURB. GREASE DUCT IS TO BE #16 GAUGE WELDED DUCT. PROVIDE CLEANOUTS AT EACH CHANGE IN DIRECTION. 3M FIREMASTER GREASE DUCT WRAP OR ALTERNATE FULLY ENCAPSULATED AND U.L. CLASSIFIED FOR 0" CLEARANCE TO COMBUSTIBLES (UL R14229) AND ENGINEER APPROVED.
- 21. 16X16 OA DUCT UP TO MAU-1. TRANSITION DUCTWORK TO FIT ROOF CURB BEFORE ROOF PENETRATION. ROOF CUTOUT FOR CURB SHALL BE 18"X18".
- 22. FIELD MOUNT FACTORY-MANUFACTURED, BARAMETRIC RELIEF HOOD TO RETURN DUCTWORK.
- 23. INSTALL SMOKE DETECTOR UPSTREAM OF BARAMETRIC RELIEF HOOD.
- 24. PULL STATION LOCATION FOR RANGE HOOD FIRE SUPPRESSION SYSTEM.
- 25. RANGE HOOD IS OWNER FURNISHED, OWNER INSTALLED.
- 26. CONCENTRIC WATER HEATER FLUE IS TO BE ROUTED FROM HEATER TO WALL AS SHOWN. INSTALLATION AND TERMINATION SHALL BE PER MANUFACTURER'S RECOMMENDATIONS. HORIZONTAL OFFSET IS TO BE AS HIGH AS POSSIBLE ABOVE BATHROOM CEILING HEIGHT. MAINTAIN 10'-0" CLEARANCE FROM TERMINATION TO PCU-1'S INTAKE.
- 27. 36"X5" MAKEUP AIR DUCT ROUTED DOWN. TERMINATION POINT SHALL BE BELOW COOKING SURFACE. ALL ELECTRICAL AND PLUMBING CONNECTIONS MUST BE LOCATED BELOW THE BACK RETURN AIR PLENUM.
- 28. TRANSFER GRILLE IS TO BE MOUNTED ABOVE COOLER ROOF, FACING OUT. PROVIDE GRILLE WITH 1/2" MESH SCREEN.
- 29. MAINTAIN EQUIPMENT MANUFACTURER'S RECOMMENDED SERVICE AREA.

PROJECT NO: 20-4047

DRAWN BY: WTD

8/30/2020





0


EWC


FLOOR PLAN -MECHANICAL


M2.01















### GENERAL NOTES:

- A. ALL OPEN-CEILING AREAS SHALL UTILIZE A RIGID DUCT CONNECTION (WITH SUPPORTS) TO DIFFUSER. DIFFUSER SHALL BE MOUNTED AT A TYPICAL ELEVATION OF 11'-0" UNLESS OTHERWISE SHOWN ON DRAWING. TYPICAL PLACEMENT OF DIFFUSER IN OPEN-CEILING AREAS ARE CENTERED BETWEEN JOISTS UNLESS SPECIFIC DIMENSION IS SHOWN ON DRAWING.
- B. ALL RECTANGULAR, ROUND, AND FLEXIBLE DUCTS SHALL BE SIZED AS SHOWN ON THESE DRAWINGS. MINIMUM INTERNAL DIMENSIONS ARE GIVEN.
- C. INSTALL TURNING VANES IN ALL 90 DEGREE SUPPLY AND RETURN DUCT ELBOWS AND AT ALL DUCT TEES.
- D. CONDENSATE DRAIN LINES SHALL BE SLOPED AT A MINIMUM 1/8" PER LINEAR FOOT OF RUN. ALL DRAIN EXITS FROM PCU-1 SHALL INCLUDE A TRAP AND CLEAN-OUT PLUG.
- E. CONTRACTOR SHALL HAVE ALL THERMOSTATS/TEMPERATURE SENSORS CALIBRATED TO MANUFACTURER'S SPECIFICATIONS PRIOR TO TURNING SYSTEM OVER TO OWNER.
- F. BALANCE DIFFUSERS AND GRILLES TO AIRFLOWS INDICATED ON PLAN. PROVIDE AIR-BALANCE REPORT TO
- G. MANUFACTURER'S RECOMMENDED CLEARANCES SHALL BE MAINTAINED FOR ALL MECHANICAL EQUIPMENT. ALL PIPING VALVES AND MANUAL VOLUME DAMPERS SHALL BE EASILY ACCESSIBLE.
- H. FLEXIBLE DUCTWORK IS ALLOWED FOR USE ON CONCEALED DUCTWORK. REFER TO DETAIL SHEET FOR MORE INFORMATION.
- I. HATCHED PORTION OF DUCTWORK SHALL BE WRAPPED WITH OWENS/CORNING ALL SERVICE FIBERGLASS DUCT WRAP, "FACED DUCT WRAP TYPE 75", 3" THICK FIBERGLASS DUCT WRAP, WITH A MINIMUM R-VALUE OF 8, FACTORY LAMINATED TO A REINFORCED FOIL KRAFT VAPOR BARRIER. REFER TO INSULATION CHART ON SHEET M1.01 FOR INSTALLATION REQUIREMENTS.
- . ANY ROUND DUCTWORK EXPOSED TO VIEW SHALL HAVE SPIRAL OUTER SHELL, LOCK—SEAM CONSTRUCTION FABRICATED FROM PAINT GRIP GALVANIZED STEEL MEETING ASTM—527 STANDARDS. ANY DUCTWORK EXPOSED TO VIEW SHALL BE CONSTRUCTED OF G90 GALVANIZED STEEL AND SHALL BE SUPPORTED AS REQUIRED WITH AIRCRAFT CABLES WITH SELF—TIGHTENING LOCKS. EXPOSED METAL DUCT SHALL BE PREPPED AND PAINTED BY OWNER.
- K. DUCTWORK, PLENUMS AND OTHER APPURTENANCES SHALL BE CONSTRUCTED OF THE MATERIALS OF THE MINIMUM WEIGHTS OR GAUGES AS REQUIRED BY THE LATEST SMACNA 2" W.G. STANDARD OR BELOW TABLE. WHEN GAUGE THICKNESS DIFFERS, THE HEAVIER GAUGE SHALL BE SELECTED. THE BELOW TABLE SHALL SERVE AS A MINIMUM.

ROUND DIAMETER	DUCT GAUGE	RECTANGULAR WIDTH	DUCT GAUGE
3-12 INCHES 13-18 INCHES 19-28 INCHES	26 GA. 24 GA. 22 GA.	3-12 INCHES 13-30 INCHES 31-54 INCHES	26 GA. 24 GA. 22 GA.

### MECHANICAL TAG NOTES:


GENERAL CONTRACTOR.

- 1. PROVIDE HIGH EFFICIENCY TAKEOFFS AND VOLUME DAMPERS IN ALL BRANCH DUCT WORK. REFER TO DETAIL ON THIS SHEET FOR ADDITIONAL INFORMATION. TYPICAL OF ALL.
- 2. INSTALL RETURN DUCTWORK AS HIGH AS POSSIBLE, HOLDING TIGHT TO STRUCTURE. BOTTOM OF DUCT WILL BE AT A MINIMUM OF 9'-0".
- 3. PROVIDE FLEX CONNECTION AT UNIT FOR SUPPLY/RETURN DUCTWORK.
- 4. FIELD MOUNT FACTORY-MANUFACTURED, BARAMETRIC RELIEF HOOD TO RETURN DUCTWORK.
- 5. CONTRACTOR TO INSTALL A 20 GAUGE RAIN SHIELD OVER ALL EXTERIOR DUCTWORK. PROVIDE WITH 16"Wx32"H ACCESS DOOR FOR DUCT MOUNTED SMOKE DETECTOR. POSITION DOOR AS CLOSE TO UNIT AS POSSIBLE. PROVIDE 34"X10" OPENING AT BOTTOM OF RAIN SHIELD (ON BOTH SIDES) TO ALLOW FOR RELIEF AIR WHEN UNIT IS IN ECONOMIZER MODE. INSTALL EXPANDED METAL GRATE OVER OPENINGS.
- 6. INSTALL SMOKE DETECTOR UPSTREAM OF BARAMETRIC RELIEF HOOD.
- 7. PROVIDE UNIT WITH 14" TALL, FULL—LENGTH EQUIPMENT CURB. DO NOT EXTEND CURB PAST UNIT. CONCRETE PAD WILL BE SLOPED 1/4" PER FOOT.
- 8. SUPPLY DUCT MAIN SHALL BE INSTALLED TO FOLLOW SLOPE OF ROOF WITHIN JOIST SPACE. ALL BRANCH DUCTWORK SHALL BE COORDINATED WITH JOIST OPENINGS.
- 9. TRANSITION FROM A 30x18 SUPPLY DUCT TO 24" AND FROM A 30x18 RETURN DUCT TO A 22X24
- 10. EXHAUST CAP AT ELEVATION OF 10'-8". REFER TO DETAIL THIS SHEET FOR MORE INFORMATION.
- 11. MAINTAIN A 10'-0" MINIMUM DISTANCE FROM EXHAUST FAN OUTLET TO MECHANICAL EQUIPMENT'S INTAKE.
- 12. FASTEN RAIN SHEILD TO CONCRETE SLAB.

PROJECT NO: 20-4047

DRAWN BY:

DATE: 8/30/2020





S ARCHITECTS & ASSOCIATE RESTON HIGHWAY LLE, KENTUCKY 40213 (502) 636-51

NEWCOMB OIL CO., LL

MECHANICAL SECTION VIEWS AND DETAILS

M3.01

P-4 <u>FOUR COMPARTMENT SINK</u>

P-TRAP, DRAIN AND ESCUTCHEONS. SINK TRIM SHALL BE AS FOLLOWS:

JOHN BOOS MODEL E4S8-1620-14T18 FOUR COMPARTMENT TYPE 300 STAINLESS STEEL SINK WITH 16"x20"x14" DEEP BOWLS, 9-3/4" HIGH BOXED BACKSPLASH, (2) 18" DRAINBOARDS AND STAINLESS STEEL LEGS WITH SIDE BRACING, STAINLESS STEEL GUSSETS AND BULLET FEET. PROVIDE WITH (4) T&S B-3990 LEVER HANDLE WASTES, CHROME SUPPLIES, STOPS, TAILPIECE,

STAINLESS STEEL HOSE, AND 4-ARM HANDLES. P-4A <u>HAND SINK - BOWL INTEGRAL TO COUNTERTOP - GOOSENECK FAUCET</u>
REFER TO ARCHITECTURAL DRAWINGS AND SPECIFICATIONS FOR COORDINATION OF LAVATORY BOWL INTEGRAL TO COUNTERTOP. PROVIDE LAVATORY DRAIN WITH INTERGRAL PERFORATED STRAINER, 3/8" RIGID SUPPLIES WITH STOPS AND P-TRAP. LAVATORY --- GOOSENECK FAUCET SHALL BE MOEN MODEL 8938 "SANI-STREAM" WITH POLISHED CHROME-PLATED CAST BRASS FAUCET BODY, 3-1/2" SPOUT, 2.0 GPM AERATOR AND WRIST BLADE HANDLES.

(1) T&S BRASS MODEL B-0290 WALL MOUNTED FAUCET WITH 12" SWING SPOUT AND 4-ARM HANDLES.

- (1) T&S BRASS MODEL B-0287-427-BC WALL MOUNTED PRE-RINSE FAUCET WITH 12" SWING SPOUT, 44" FLEXIBLE

P-4B <u>HAND SINK - WALL-HUNG</u> MANSFIELD GRAND ISLE MODEL 2018HBNS VITREOUS CHINA LAVATORY WITH 4" CENTER FAUCET HOLES. PROVIDE CONCEALED ARM CARRIER, LAVATORY DRAIN WITH INTERGRAL PERFORATED STRAINER, 3/8" RIGID SUPPLIES WITH STOPS AND P-TRAP AND ADA COMPLIANT TRAP WRAP. MOUNT LAVATORY AT ADA HEIGHT. LAVATORY TRIM SHALL BE AS FOLLOWS: --- SINGLE HANDLE FAUCET SHALL BE AMERICAN STANDARD RELIANT 3 MODEL 7385.004 WITH POLISHED CHROME-PLATED CAST BRASS FAUCET BODY WITH 1.2 GPM AERATOR.

P-5 MOP BASIN - 24"x24" - RECESSED IN FLOOR ZURN MODEL Z1996-24 MOP SERVICE BASIN WITH MOLDED HIGH DENSITY COMPOSIT BASIN, PVC DRAIN BODY, STAINLESS STEEL STRAINER AND 3" GASKETED OUTLET CONNECTION. BASIN SHALL BE RECESSED IN CONCRETE FLOOR. REFERENCE DETAIL ON DRAWING A-551 FOR ADDITIONAL INFORMATION.

IPS CORPORATION WATER-TITE MODEL AB9702HA ICE MAKER OUTLET BOX WITH INTEGRAL WATER HAMMER ARRESTOR AND PRELOADED NAILS. FIELD PAINT EXPOSED PORTION OF BOX TO MATCH ADJACENT WALL SURFACES. VERIFY PIPE CONNECTION TYPE PRIOR TO ORDERING.

WOODFORD MODEL 24 ANTI-SIPHON WALL FAUCET WITH VACUUM BREAKER, REMOVABLE KEYED HANDLE, LOOSE TEE KEY AND ¾" COLD WATER INLET.

WOODFORD MODEL 24 ANTI-SIPHON WALL FAUCET WITH VACUUM BREAKER, WHEEL HANDLE, LOOSE TEE KEY AND ¾" HOT

CONCEALED HOSE BIBB — COLD WATER
WOODFORD MODEL MB24 ANTI-SIPHON WALL FAUCET WITH MODULAR BOX, VACUUM BREAKER, WHEEL HANDLE, LOOSE TEE KEY AND ¾" COLD WATER INLET.

WOODFORD MODEL 65 ANTI-SIPHON AUTOMATIC DRAINING FREEZELESS WALL HYDRANT WITH VACUUM BREAKER, LOOSE TEE KEY AND ¾" COLD WATER INLET.

PLUMBING LEGEND ABOVE FINISHED FLOOR AREA DRAIN CLEANOUT CW COLD WATER ELECTRICAL CONTRACTOR EXTERIOR CLEANOUT (PVC FEMALE ADAPTER W/ BRASS CAP) FLOOR DRAIN FREEZE PROOF WALL HYDRANT GENERAL CONTRACTOR GREASE INTERCEPTOR HOSE BIBB HOT WATER MECHANICAL CONTRACTOR OPEN RECEPTACLE PLUMBING CONTRACTOR POLYVINYL CHLORIDE PVC TYP VENT THROUGH ROOF VTR WATER HEATER SANITARY PIPING GREASE WASTE PIPING STORM PIPING SANITARY VENT PIPING -----DOMESTIC COLD WATER PIPING DOMESTIC HOT WATER PIPING (110° F) FILTERED COLD WATER NATURAL GAS PIPING PRESSURE GAUGE SOLENOID VALVE GAS SHUT-OFF VALVE BALL VALVE SHUT-OFF VALVE AT EQUIPMENT BALL VALVE IN RISER PIPING ELBOW (TURNED UP/DOWN) PIPING TEE (TURNED UP/DOWN) 


WATER FILTER; EVERPURE MODEL HIGH FLOW CSR WH QUAD - MC2. — 1-1/2" WILKINS MODEL 375ST BACKFLOW PREVENTER WITH STAINLESS STEEL STRAINER AND AIR GAP. \_\_\_\_\_\_ --- PRESSURE GAUGE (TYPICAL) TO WATER CLOSETS — ⊩—ALL PIPE FITTING AND STAND-OFFS WITHIN THE OUTLINED AREA SHALL BE STAINLESS STEEL. MAIN SHUT-OFF VALVE ½" ARMAFLEX INSULATION — AT EACH FLOOR PENETRATION (TYPICAL) FINISH FLOOR 1½" DOMESTIC WATER FROM └──1" DOMESTIC WATER OUT TO SITE STA-RITE MODEL SNCP42, ½ HP — JET PUMP WITH SURGE TANK AND └─ PEX FCW PIPING - THESE PIPES SHALL BE DOWN TO BELOW SLEEVED TO OUTSIDE PRESSURE RELIEF VALVE. THE CONCRETE PAD. DOMESTIC WATER ENTRY PIPING SCHEMATIC NOT TO SCALE


SANITARY WASTE AND VENT RISER DIAGRAM

20-4047 DRAWN BY:

8/30/2020

PROJECT NO:







PLUMBING LEGEND AND DETAILS

P1.01

NOT TO SCALE





PLUMBING TAG NOTES:

FURNISH AND INSTALL A 1000 GALLON PRECAST CONCRETE GREASE TRAP. EXACT LOCATION SHALL BE SITE SPECIFIC AND DETERMINED BY OWNER.

3" SANITARY OUT TO SITE 5'-0". REFERENCE CIVIL DRAWINGS FOR CONTINUATION. COORDINATE EXACT LAYOUT OF EXTERIOR SANITARY WITH OWNER AND SITE PLAN

4" SANITARY OUT TO SITE 5'-0". REFERENCE CIVIL DRAWINGS FOR CONTINUATION. COORDINATE EXACT LAYOUT OF EXTERIOR SANITARY WITH OWNER AND SITE PLAN PRIOR TO ROUGH-IN.

CONDENSATE LINE FROM HVAC EQUIPMENT SHALL BE CONNECTED TO THE DOWNSPOUT COLLECTION DRAIN LINE.

### PLUMBING GENERAL NOTES:


- PLUMBING CONTRACTOR SHALL PROVIDE AS-BUILT DRAWINGS WITH DIMENSIONED LOCATIONS OF SANITARY, WATER AND GAS LINES. REFERENCE GENERAL NOTE "A" FOR PHOTOGRAPHING REQUIREMENTS. LOCATION, DIRECTION AND CORRESPONDING NUMBER OF EACH PHOTOGRAPH SHALL BE INDICATED ON THE AS-BUILT DRAWINGS.
- THE OWNER SHALL CHECK WALLS FOR LOCATIONS OF ALL PLUMBING LINES PRIOR TO DRYWALL BEING INSTALLED.
- PLUMBING CONTRACTOR SHALL CAULK OR FOAM ALL WALL/CEILING PENETRATIONS MADE AS A RESULT OF PLUMBING PIPING INSTALLATION PRIOR TO INSULATION BEING INSTALLED TO IMPROVE THE VAPOR BARRIER. COORDINATE THIS WORK WITH THE GENERAL CONTRACTOR.
- THE FOUR COMPARTMENT SINK LIP SHALL BE SET AT 39" ABOVE FINISH FLOOR.
- . ALL TRENCHES UNDER PAVEMENT SHALL BE FILLED WITH STONE.
- ALL TOILET FLANGES SHALL BE CAST IRON OR STAINLESS STEEL.
- ALL INTERIOR AND EXTERIOR DOMESTIC WATER PIPING SHALL BE CROSS-LINKED POLYETHYLENE (PEX OR EQUAL).
- ALL INTERIOR DOMESTIC WATER LINES SHALL BE 3/4" MINIMUM. WATER LINES SERVING
- FLUSH VALVES SHALL BE 11/4".
- ALL DOMESTIC WATER LINES ENTERING AND EXITING THE BUILDING BELOW GRADE SHALL BE INSTALLED IN A SLEEVE FROM THE POINT WHERE THEY PENETRATE THE FLOOR TO BEYOND THE BLACK CONCRETE OR THE EQUIPMENT PAD, DEPENDING ON WHAT DIRECTION THEY EXIT THE BUILDING.
- ALL WATER LINES SHALL BE SPACED 2" APART WHERE THEY PENETRATE THE FLOOR SLAB FOR EASE OF FUTURE MAINTENANCE.
- ALL SHUT-OFF VALVES ON DOMESTIC WATER LINES SHALL BE TAGGED WITH  $3\frac{1}{2}$ "x  $1\frac{1}{2}$ " ENGRAVED LAMINATED OR BRASS TAGS.
- PLUMBING CONTRACTOR SHALL FURNISH AND INSTALL A FIVE POUND ANODE ON ALL FREEZE PROOF WATER HYDRANTS. GENERAL CONTRACTOR SHALL PROVIDE THE OWNER WITH PHOTOGRAPHS OF ALL ANODES TO VERIFY INSTALLATION.
- GAS AND WATER UTILITY ENTRANCES INTO THE BUILDING SHALL BE SLEEVED TO OUTSIDE THE CONCRETE PADS.
- PRIOR TO TOILETS BEING SET, THE PLUMBING CONTRACTOR SHALL VERIFY FLATNESS OF THE FLOOR WITH THE GENERAL CONTRACTOR TO ENSURE EACH TOILET WILL BE IN COMPLETE CONTACT WITH THE FLOOR AND NO SHIMS WILL BE REQUIRED.
- . EXTERIOR SEWER CLEANOUTS SHALL BE PLACED WHERE INDICATED ON THE PLANS AND/OR A MAXIMUM OF 95'-0" APART.
- . ALL OUTSIDE CLEANOUTS SHALL BE BRASS.
- ALL SANITARY AND GREASE WASTE PIPING SHALL BE SCHEDULE 40 PVC.

PROJECT NO: 20-4047 DRAWN BY:

WTD DATE: 8/30/2020

0

FLOOR PLAN - SANITARY WASTE AND VENT



FLOOR PLAN - WATER AND GAS

**√P2.02** /

SCALE: 1/8"=1'-0"

### PLUMBING FIXTURE SCHEDULE

DESIGNATOR	FIXTURE	CW	HW	SAN	VEI
P-1	WATER CLOSET — FLOOR SET — FLUSH VALVE	11/4"		4"	2
P-1A	WATER CLOSET — FLOOR SET — FLUSH VALVE — ADA	11/4"		4"	4
P-2	LAVATORY — INTEGRAL TO COUNTERTOP	1/2"	1/2"	1½"	11/2
P-3	URINAL — ADA	3/4"		2"	1½
P-4	FOUR COMPARTMENT STAINLESS STEEL SINK	3/4"	3⁄4"	2"	1½
P-4A	ONE COMPARTMENT HAND SINK INTEGRAL TO COUNTERTOP	1/2"	1/2"	1½"	11/2
P-4B	WALL-HUNG HAND SINK	1/2"	1/2"	1½"	1½
P-5	RECESSED MOP BASIN - 24"x24"			3"	11/2
P-6	ICE MAKER CONNECTION BOX	½"			
НВ	COLD WATER HOSE BIBB	3/4"			
HB-1	HOT WATER HOSE BIBB		3⁄4"		
HB-2	CONCEALED COLD WATER HOSE BIBB	3⁄4"			
FPWH	FREEZE-PROOF WALL HYDRANT	3⁄4"			
FD-1	SQUARE TOP FLOOR DRAIN — 3" OUTLET			3"	11/2

- PIPE SIZES ARE AS INDICATED UNLESS OTHERWISE NOTED ON FLOOR PLANS AND RISER DIAGRAMS.
- MINIMUM 2" SANITARY PIPING UNDERGROUND.
  - PROVIDE ALL REQUIRED PIPING TO FIXTURES INDICATED ON THE FLOOR PLANS, INDICATED WITH A "P" DESIGNATION. PROVIDE PIPING OF SIZE INDICATED IN THIS SCHEDULE.
- PIPE ALL EQUIPMENT (SUPPLIED BY OTHERS) AS REQUIRED TO OBTAIN A FULL AND OPERATIONAL SYSTEM PROVIDE BACKFLOW PROTECTION AS/IF REQUIRED BY THE DETAILS AND BY THE STATE PLUMBING CODE ALL EQUIPMENT SHALL BE CONNECTED PER THE MANUFACTURER'S REQUIREMENTS. THE PLUMBING CONTRACTOR SHALL ALSO INSTALL ANY DRAIN PIPING CONNECTIONS AND SPILL INDIRECTLY TO EITHER AN OPEN RECEPTACLE OR FLOOR DRAIN. REFER TO ARCHITECTURAL PLANS FOR EXACT PLACEMENT OF ALL EQUIPMENT.

PLUMBING TAG NOTES:

- (1) 1½" AND (1) 1" DOMESTIC WATER LINES OUT TO SITE. REFERENCE CIVIL DRAWINGS FOR CONTINUATION. WATER LINES MUST BE CONTINUOUS WITH NO JOINTS
- FURNISH AND INSTALL 1½" WILKINS MODEL 375 BACKFLOW PREVENTER WITH AIR GAP AND STRAINER. REFERENCE THE DOMESTIC WATER ENTRY PIPING SCHEMATIC ON DRAWING P1.01 FOR ADDITIONAL INFORMATION.
- FURNISH AND INSTALL 6" PVC SLEEVE BELOW SLAB WITH (2) 45" ELBOWS ON EACH
- (1) 1½" AND (1) 1" DOMESTIC WATER LINES UP FROM BELOW SLAB. REFERENCE DOMESTIC WATER ENTRY SCHEMATIC ON DRAWING P1.01 FOR ADDITIONAL
- NATURAL GAS SERVICE OUT TO SITE. COORDINATE PIPE MATERIAL, SIZE AND GAS PRESSURE WITH LOCAL UTILITY COMPANY.
- FURNISH AND INSTALL NEW NATURAL GAS METER PER LOCAL UTILITY COMPANY
- EXTEND 1" GAS TO COOLING UNIT AND CONNECT. FURNISH AND INSTALL GAS
- EXTEND 3/4" GAS TO MAKE-UP AIR UNIT ON ROOF AND CONNECT. FURNISH AND INSTALL 6" DIRT LEG AND GAS SOLENOID VALVE. INTERCONNECT GAS SOLENOID VALVE TO HOOD FIRE SUPPRESSION SYSTEM. COORDINATE THIS WORK WITH THE ELECTRICAL CONTRACTOR.
- . EXTEND 1" GAS TO WATER HEATER AND CONNECT. FURNISH AND INSTALL GAS SHUT-OFF VALVE AND 6" DIRT LEG.
- . <u>WH-1</u> FURNISH AND INSTALL A RINNAI MODEL RL75i(VC2528FFUD-US), TANKLESS GAS FIRED WATER HEATER WITH MINIMUM INPUT OF 10,300 BTUH AND A MAXIMUM INPUT OF 180,000 BTUH.
- 1. ROUTE 1½" GAS HEADER LOW ON WALL BEHIND COOKING EQUIPMENT. FURNISH AND INSTALL GAS QUICK CONNECT AND GAS SHUT-OFF VALVE AT EACH PIECE OF EQUIPMENT AND PROVIDE (1) 3/4" QUICK CONNECT AND GAS SHUT-OFF VALVE FOR FUTURE CONNECTION.
- 12. FURNISH AND INSTALL GAS SOLENOID VALVE. INTERCONNECT WITH HOOD FIRE SUPPRESSION SYSTEM.
- 3. FURNISH AND INSTALL 8" PVC SLEEVE BELOW SLAB WITH (2) 45" ELBOWS ON EACH
- 4. APPROXIMATE LOCATION OF PRESSURE ASSIST PUMP. REFERENCE DOMESTIC WATER ENTRY PIPING SCHEMATIC ON DRAWING P1.01 FOR ADDITIONAL INFORMATION.
- 15. HOSE BIBB SHALL BE MOUNTED 18" ABOVE FINISH FLOOR AND 64" OFF OF THE INSIDE CORNER BY THE FOUR COMPARTMENT SINK.
- 6. FURNISH AND INSTALL A ZURN MODEL QCM43-6GX COPPER MANIFOLD AT EACH GROUP OF SHUT-OFF VALVES LOCATED WITHIN CABINET SPACE.
- 7. PROVIDE BRASS TAG LABELS AND SHUTOFF VALVES IN THIS AREA FOR WATER PIPING AT EACH WALL OR FLOOR PENETRATION.

NEW GAS METER LOAD:	
HVAC AIR HANDLING UNIT —	150,000 BTUH
DOMESTIC WATER HEATER —	180,000 BTUH
MAKE-UP AIR UNIT -	109,600 BTUH
KITCHEN EQUIPMENT —	313,000 BTUH
TOTAL CONNECTED LOAD —	752,600 BTUH

FLOOR PLAN - WATER


P2.02


20-4047 DRAWN BY: WTD


8/30/2020


SOCIA


AND GAS














EXTERIOR LIGHTING TIMECLOCK:

TYPE	DESCRIPTION	MODEL	LAMPS	REMARKS	VOLTAGE
A4 78 FIXTURES	4' LED WITH HIGH STRENGTH POLYMER REFLECTOR AND HOUSING WITH TROUGH WIRING CHANNEL AND SURFACE OR SUSPENDED MOUNTING. PROVIDE 4000 LUMEN PACKAGE WITH 3500K COLOR TEMPERATURE.	LSI DW HO CW UE	LED'S INCLUDED.	PROVIDE WITH A MINIMUM 80 CRI AND 10 YEAR WARRANTY  MOUNT AT 11' ABOVE FINISHED FLOOR.	120V
C 4 FIXTURES	SURFACE VAPOR TIGHT LED WITH IMPACT RESISTANT FIBERGLASS HOUSING AND POLYCARBONATE LENS. PROVIDE WITH 3500K COLOR TEMPERATURE AND 6000 LUMEN OUTPUT.	LSI EG3 4 S LED HO CW UE	LED'S INCLUDED.	PROVIDE WITH A MINIMUM 80 CRI AND MINIMUM LM-80 RATING.	120∨
EB 1 FIXTURE	LED COMPATIBLE, 125W, 90 MINUTE, SINE WAVE INVERTER WITH MAINTENANCE FREE BATTERY.	IDTA IIS 125 SM	NO LAMPS	PR□VIDE SURFACE M□UNTED IN ST□RAGE R□□M AS INDICATED.	120∨
F 2 FIXTURES	6' RECESSED LED DOWNLIGHT WITH SPECIFICATION GRADE REFLECTOR AND GALVANIZED STEEL FRAME.	RP 61100358/IC630C	LED'S INCLUDED.		120∨
G 12 FIXTURES	LED SURFACE LIGHT WITH 5700K COLOR TEMPERATURE, DIE CAST ALUMINUM HOUSING WITH SYMMETRIC TYPE 5 DISTRIBUTION.	LSI CRU SM SC LED HD CW UE MSV	LED'S INCLUDED.	PROVIDE WITH A MINIMUM 69 CRI. PROVIDE WITH A MINIMUM 90 LUMENS PER WATT PROVIDE WITH A MINIMUM 90% LUMEN MAINTENANCE AT 50,000 HOURS OF USE.	120∨
H	LED COVE LIGHTING.	(1) LSI-LDL3-12-LED-CW-24 (6) LSI LDL3-48-LED-CW-24 (6) LSI 12" JUMPER 35148302 (1) LSI RPSE40 LED 120 PDWER SUPPLY (2) LSI RPSE100 LED 120 PDWER SUPPLY	LED'S INCLUDED.	PROVIDE LENGTH AS INDICATED ON PLANS. PROVIDE WITH A MINIMUM 85 CRI.	120∨
J 7 FIXTURES	18' STEMS WITH CANDPY.	(7) LSI-AUP-S-LED-HO-NW ACF16 GWT FROSTED LENS (7) LSI BC 600 3 GWT CANOPY	LED'S INCLUDED.	PROVIDE WITH 18" DOWN ROD FOR MOUNTING BELOW BEAMS	120∨
K 8 FIXTURES	100 WATT 9" PENDANT WITH GALVANIZED HOUSING AND BLACK CORD.	BARNLIGHT BLE-C-LAR PC. LED12 975 SBK 1250 FL 120	LED'S INCLUDED.	COORDINATE SUSPENSION LENGTH WITH OWNER AND ARCHITECT.	120∨
M 3 FIXTURES	WALL MOUNT LED WITH CAST ALUMINUM HOUSING AND TEMPERED GLASS LENS.	LSI PWMS LED HO CW UE BLK	LED'S INCLUDED.		120∨
	TYPE "O" DELETED.				
X1 1 FIXTURE	EXIT LIGHT WITH DUAL HEAD EMERGENCY LIGHTING AND BATTERY BACK UP.	LSI PRX RU BK LD11	LED'S INCLUDED.	PROVIDE WITH BATTERY CAPACITY TO POWER ALL ASSOCIATED EMERGENCY HEADS FOR 90 MINUTES.	120∨
XX 2 FIXTURES	DUAL HEAD EXTERIOR REMOTE EMERGENCY LIGHTING HEADS	LSI 2TMLED BLK	LAMPS INCLUDED	PROVIDE BATTERY BACK UP FROM NEAREST EXIT SIGN AS INDICATED ON PLANS.	120∨
X2 3 FIXTURES	EXIT LIGHT WITH DUAL HEAD EMERGENCY LIGHTING AND BATTERY BACK UP.	LSI LPRX R U BK LD11 R	LED'S INCLUDED.	PROVIDE WITH BATTERY CAPACITY TO POWER ALL ASSOCIATED EMERGENCY HEADS FOR 90 MINUTES.	120∨
XX2 2 FIXTURES	SINGLE HEAD EXTERIOR REMOTE EMERGENCY LIGHTING HEADS	LSI TMLED WI BLK	LAMPS INCLUDED	PROVIDE BATTERY BACK UP FROM NEAREST EXIT SIGN AS INDICATED ON PLANS.	120∨
CEILING FANS 3 FIXTURES		MEJA 52° CEILING FAN, FLUSH MOUNTED CEILING, WHITE			

LIGHT FIXTURE SCHEDULE

LIGHT SWITCH GENERAL PURPOSE

DUAL TECHNOLOGY, ULTRASONIC WALL MOUNTED TYPE OCCUPANCY SENSOR

CEILING MOUNTED OCCUPANCY SENSOR

2'-0' FLUDRESCENT WALL MOUNT

2'x2' FLUDRESCENT TROFFER

2'x4' FLUDRESCENT TROFFER

1'x4' FLUORESCENT TROFFER

DUPLEX - SAFETY TYPE

DUPLEX (ABOVE COUNTERTOP)

GANG RECEPTACLE IN COMBINATION WITH SWITCH (PROVIDE DIVIDER IF LIGHTING CIRCUIT IS 277V)

DUPLEX WITH INTEGRAL GROUND FAULT PROTECTION

QUADRUPLEX RECEPTACLE

208/10 RECEPTACLE, AS NOTED

208/3¢ RECEPTACLE, AS NOTED

WEATHER RESISTANT DUPLEX - WITH WEATHER-PROOF 'WHILE IN USE' TYPE DIE-CAST METAL COVERPLATE WITH LOCKABLE ENCLOSURE AT DUTLET. INTERMATIC GAURDIAN SERIES OR EQUAL.

MAGNETIC COMBINATION STARTER

EMERGENCY PANELBUARD, SURFACE OR FLUSH MOUNTED NORMAL PANELBUARD, SURFACE OR FLUSH MOUNTED

MECHANICAL EQUIPMENT DESIGNATUR (SEE MECH, SCHEDULES)

PROVIDE CONNECTION TO HAND DRYER

PLUMBING FIXTURE ELECTRIC EYE TRANSFORMER
CONNECTION. TRANSFORMER SHALL BE 120V-24V. MOUNT
ABOVE SUSPENDED ACCESSIBLE CEILING IN J-BOX.
PROVIDE ADDITIONAL TRANSFORMERS OF SAME TYPE
AS/IF NEEDED.

M.E.S. (MAJOR EQUIPMENT SCHEDULE) # INDICATOR

ENCLOSED FLUSH MTD. CIRCUIT BREAKER

MISC. DUPLEX - SURGE SUPPRESSION TYPE

DUPLEX - WALL MOUNTED

DISCONNECT SWITCH

MAGNETIC STARTER

WEATHERPROOF

REVISION NOTE

JUNCTION BOX

EXIT LIGHT(CEILING, WALL MOUNT)

DOWNLIGHT

SIMPLEX

DUPLEX

PILOT LIGHT SWITCH (ILLUMINATED WHEN

DIMMER SWITCH

LIGHTING

SHADING
INDICATES
EMERGENCY
OPERATION,
DIAGONAL
SLASH
INDICATES
RECESSED

POWER OUTLETS

THREE-WAY SWITCH

4'-0**"** 

4'-0"

4′-0**″** 

4′-0**″** 

4′-0″

6'-6**"** 

CEIL.

CEIL.

CEIL.

CEIL.

1'-6"

1'-6"

5′-0**″** 

5′-0**″** 

5′-0**″** 

AS AS NOTED

 $\Theta$ 

 $\ominus$ 

 $\bigoplus$  s

 $\bigoplus$ 

 $\not$ 

**⊖** GFI

⊕ c\2

52

**←** v

₩P

 $> \!\!\!<$ 

WP

<del>-</del>

6'-6" TO TOP 6'-6' TO TOP

/\_NEUTRAL *₩* ---Ø

Şpl

MUSIC DISTRIBUTION BOX

PLUMBING FIXTURE SOLENDID VALVE/ ELECTRIC EYE SENSOR CONNECTION. COORDINATE EXACT CONNECTION REQUIREMENTS WITH MANUFACURER.

REQUIRED. PROVIDE ADDITIONAL TRANSFORMERS OF SAME TYPE AS/IF

DATA DUTLET: NUMBER BESIDE
DUTLET INDICATES NUMBER OF DATA
JACKS TO BE PROVIDED AND
INSTALLED. IF NO NUMBER IS
INDICATED, THERE SHALL BE ONLY
ONE DATA JACK.

CONTRACTOR SHALL PROVIDE DETAILED AS BUILT DOCUMENTS UPON

COMPLETION OF CONSTRUCTION INCLUDING A DIMENSIONED PLAN SHOWING

GENERAL NOTES (APPLICABLE TO ALL WORK AND DOCUMENTS):

1. EACH CONTRACTOR, PROPOSER, SUPPLIER AND/OR MANUFACTURER SHALL REFER TO ALL DOCUMENTS PERTAINING TO THIS PROJECT AND COORDINATE ACCORDINGLY SO AS TO INSURE ADEQUACY OF FIT, COMPLIANCE WITH SPECIFICATIONS, PROPER VOLTAGE AND CURRENT CHARACTERISTICS TO AVOID CONFLICT

2. OBSERVE ALL APPLICABLE CODES, RULES AND REGULATIONS THAT MAY APPLY TO THE WORK UNDER THIS CONTRACT. (CITY, COUNTY, LOCAL, STATE, FEDERAL, MUNICIPALITY, UTILITY COMPANY, OSHA, ETC.)

3. INSTALL EQUIPMENT, MATERIALS, ETC. IN STRICT ACCORD WITH MANUFACTURERS' RECOMMENDATIONS AND DIRECTIONS. IF IN CONFLICT WITH THE DESIGN INDICATED IN CONTRACT DOCUMENTS, ADVISE THE

4. THE PURPOSE AND INTENT OF ALL OF THE DOCUMENTS PERTAINING TO THIS PROJECT IS TO PROVIDE A COMPLETE, FUNCTIONAL, SAFE, LIKE NEW FACILITY. ANYTHING LESS SHALL BE UNACCEPTABLE.

BUILDING, MAKE SUCH PENETRATIONS IN A WAY THAT WILL NOT VOID OR DIMINISH THE ROOFING WARRANTY OR INTEGRITY IN ANYWAY. COORDINATE ALL SUCH PENETRATIONS WITH THE ROOFING INSTALLER.

7. UNLESS OTHERWISE SPECIFIED OR INDICATED, INSTALL LIGHT FIXTURES, DIFFUSERS, REGISTERS, GRILLES, SPRINKLER HEADS, SMOKE DETECTORS AND OTHER CEILING MOUNTED APPURTENANCES IN THE CEILING IN A

8. ANY VIBRATING, OSCILLATING OR OTHER NOISE OR MOTION PRODUCING EQUIPMENT SHALL BE ISOLATED

EXPENSE. THE FINAL DECISION ON THE SUITABILITY OF A PARTICULAR INSTALLATION'S ACCEPTABILITY

ASSEMBLY IS NOT ACCEPTABLE AS MEETING THIS REQUIREMENT, UNLESS WAIVED BY THE ENGINEER IN

10. ALL SUPPORTS FOR EQUIPMENT, DEVICES OR FIXTURES SHALL BE UNIQUE, FROM THE BUILDING STRUCTURE. DO NOT SUPPORT WORK FROM OTHER TRADES, EQUIPMENT OR SUPPORTS WITHOUT WRITTEN PERMISSION FROM THE ENGINEER AND CONSENT OF THE OTHER TRADE, IN WRITING.

11. WHERE EXIT LIGHTS ARE CONNECTED TO EMERGENCY CIRCUITS WITH KEYSWITCH OR CONTACTOR CONTROL, AN UNSWITCHED LINE SHALL BE PULLED IN TO MAINTAIN THEIR OPERATION REGARDLESS OF SWITCH

12. WHERE EXIT SIGNS OR EMERGENCY BATTERY PACKS ARE PROVIDED, THEY SHALL BE CONNECTED TO AN

13. WHERE OUTLETS ARE LOCATED APPROXIMATELY BACK-TO-BACK ON OPPOSITE SIDES OF A PARTY WALL. THE OUTLETS SHALL NOT BE INSTALLED IN THE SAME STUD SPACE, BUT SHALL BE SEPARATED BY A

14. ALL MATERIALS FURNISHED AND ALL WORK INSTALLED SHALL COMPLY WITH THE CURRENT EDITION OF THE NATIONAL ELECTRICAL CODES, NATIONAL FIRE CODES OF THE NATIONAL FIRE PROTECTION ASSOCIATION, THE REQUIREMENTS OF LOCAL UTILITY COMPANIES, AND WITH THE REQUIREMENTS OF ALL GOVERNMENTAL AGENCIES OR DEPARTMENTS HAVING JURISDICTION. IF ANY CONFLICTS OR DISCREPANCIES OCCUR THE MOST STRINGENT SHALL APPLY.

15. DO NOT SCALE FROM DRAWINGS, AS PRINTING DISTORTS SCALE. WORK SHALL BE LAID OUT FROM DIMENSIONED DRAWINGS, OR DIMENSIONS SUPPLIED TO THE CONTRACTOR.

16. IF A CANOPY DEDICATED TO DISPENSING DIESEL FUEL IS TO BE CONSTRUCTED, PROVIDE WIRING FOR AN EMRGENCY STOP OUTSIDE OF THE BUILDING ON THE CLOSEST CORNER.

MINIMUM OF ONE STUD, UNLESS OTHERWISE APPROVED BY THE ARCHITECT.

FROM SURROUNDING SYSTEMS IN AN APPROVED MANNER. NOISY OR STRUCTURALLY DAMAGING INSTALLATIONS SHALL BE SATISFACTORILY REPLACED OR REPAIRED AT THE INSTALLING CONTRACTORS'

9. ALL ELECTRICAL COMPONENTS OR EQUIPMENT SHALL BE LABELED BY UNDERWRITER'S LABORATORIES OR OTHER APPROVED LISTING AGENCY. APPROVED AND LABELING OF INDIVIDUAL COMPONENTS ON AN

SYMMETRICAL PATTERN, UNLESS SPECIFICALLY INDICATED OTHERWISE ON THE ARCHITECTUAL REFLECTED

5. WHERE PENETRATING ROOFING MEMBRANE OR OTHER MATERIALS USED FOR WEATHERPROOFING TH

6. REFER TO ARCHITECTURAL FLOOR PLANS, ELEVATIONS AND CASEWORK DETAILS FOR LOCATION OF

AS BUILT DRAWINGS:

LOCATIONS OF ALL CONDUITS.

ENGINEERS PRIOR TO INSTALLATION FOR CLARIFICATION.

PLUMBING FIXTURE ELECTRIC EYE
TRANSFORMER CONNECTION. TRANSFORMER
SHALL BE 120V- 24V AND SUPPLIED WITH
PLUMBING FIXTURE. MOUNT ABOVE
SUSPENDED ACCESSIBLE CELLING AS
BEOLUPE REPORTED ADDITIONAL

BMP DATE: 8/30/2020

DRAWN BY:

20-4047

PROJECT NO:

SOCIA

**NEWCOMB** 

ELECTRICAL LEGEND AND DETAILS

E1.00

03 DELI HOOD FAN SAFETY SWITCH DETAIL 04 PART. ELEC. ROOM TROUGH ELEVATION 05 PART. ELEC. ROOM TROUGH ELEVATION

### GENERAL NEW WORK NOTES (LIGHTING):

- A. REFER TO THE ARCHITECT'S REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF ALL CEILING MOUNTED LIGHT FIXTURES ETC. REFER ALSO TO THE ARCHITECT'S CASEWORK DETAILS AND ROOM ELEVATIONS FOR EXACT LOCATIONS AND MOUNTING HEIGHTS OF LIGHT FIXTURES, ETC.
- B. ALL NEW WRING SHALL BE #12 WITH A #12 INSULATED GROUND WIRE (U.O.N.). CONDUIT SHALL BE 3/4" MINIMUM.
- C. CONTRACTOR SHALL FOLLOW BRANCH CIRCUITING LAY-OUT, AS INDICATED ON THE FLOOR PLANS, WITH A MAXIMUM OF THREE (3) BRANCH CIRCUITS PER HOMERUN. EACH BRANCH CIRCUIT SHALL BE PROVIDED WITH A DEDICATED NEUTRAL CONDUCTORS. DEDICATED NEUTRAL CONDUCTORS SHALL BE CONSIDERED CURRENT CARRYING. IF ADDITIONAL CONDUCTORS ARE RAN IN THE SAME CONDUIT WITH THOSE INDICATED, CONTRACTOR SHALL DERATE ALL CURRENT CARRYING CONDUCTORS PER N.E.C. #310.15(B)(3), AND UPSIZE CONDUIT AS REQUIRED PER N.E.C. #300.17 AND ANNEX C. MULTIWIRE BRANCH CIRCUITS AS DEFINED IN N.E.C #100 / 210.4 (CIRCUITS SHARING A COMMON NEUTRAL CONDUCTOR) SHALL NOT BE PERMITTED.
- D. ALL UNDERGROUND TRENCHES SHALL BE FILLED WITH STONE.
- E. MC CABLING SHALL BE ACCEPTABLE WHERE CONCEALED IN WALLS AND CEILINGS. EMT SHALL BE USED AT ALL EXPOSED LOCATIONS.
- F. A DIMENSIONED AND DETAILED AS-BUILT PLAN SHALL BE PROVIDED BY THE CONTRACTOR INDICATING ALL CONDUIT ROUTES. THE CONTRACTOR SHALL TAKE AND PROVIDE PHOTOS OF ALL UNDERGROUND UTILITIES PRIOR TO COVERING OF
- G. ALL EMPTY CONDUITS FOR FUTURE USE SHALL BE PROVIDED WITH A PULL
- H. ALL CONDUITS STUBBED UP FROM FLOOR INTO WIRING TROUGH SHALL BE SEALED AS REQUIRED FOR GAS SEALS. THIS SHALL APPLY TO ALL CONDUITS IN THE TROUGH WHETHER SERVING GAS EQUIPMENT OR NOT.
- I. ALL SWITCHES SHALL BE MOUNTED AS TIGHT TO DOOR FRAMES AS POSSIBLE TO MAXIMIZE AVAILABLE WALL SPACE. PROVIDE MULTIGANG SWITCHBOXES WHEREVER POSSIBLE. NO SWITCHES SHALL BE MOUNTED ANY MORE THAN 12" FROM DOOR FRAME.

### TAGGED NOTES:

1. DECORATIVE GRAPHICS LIGHTING J—BOX. ROUTE ALL CONDUIT AND WIRING CONCEALED TO SIGNAGE. PROVIDE BOX IN VERTICAL FACE OF SOFFIT AS REQUIRED. CONNECTION SHALL BE CENTERED OVER SHELVING AND LOCATED 9" ABOVE THE TOP OF THE OPENING. CONTROL WITH INTERIOR LIGHTING. PROVIDE WITH 14–1/2" WIDE X 6" TALL X 4" DEEP JUNCTION BOX ACCESSIBLE FROM THE MANAGER'S OFFICE WITH ONE CIRCUIT AND NIPPLE OUT THE BACKSIDE TO FEED SIGN. MOUNT 8–1/2" ABOVE FINISHED OPENING CENTERED OVER SHELVING. COORDINATE EXACT ELEVATION WITH ALL TRADES PRIOR TO ROUGH—IN.

- 2. EXTERIOR LIGHTING CIRCUIT SHALL BE CONTROLLED THROUGH EXTERIOR LIGHTING PHOTOCELL AS REQUIRED. PROVIDE UNSWITCHED CONDUCTOR BYPASSING PHOTOCELL FOR CONNECTION TO BATTERY BACK UP.
- 3. FREEZER VAPOR PROOF LIGHT PROVIDED WITH COOLER SHALL NOT BE CONNECTED.
- 4. PROVIDE SWITCH AT LOCATION INDICATED FOR OVERRIDE OF OCCUPANCY SENSOR IN ROOM. SWITCH SHALL PROVIDE BYPASS OF OCCUPANCY SENSOR RELAY AS REQUIRED FOR OVERRIDE.
- 5. PROVIDE CONNECTIONS TO SITE LIGHTING POLES AS REQUIRED BY SITE PLAN. PROVIDE ADDITIONAL CIRCUIT TO EACH LIGHTING POLE FOR BASE MOUNTED RECEPTACLE. RECEPTACLE SHALL BE MOUNTED ON POLE BASE AND NOT AT POLE ACCESS BOX. REFER TO SITE SPECIFIC DRAWINGS FOR FURTHER REQUIREMENTS.
- 6. REFER TO SITE SPECIFIC PLANS FOR EXACT SIGN LOCATIONS AND REQUIREMENTS. SITE SIGNAGE SHALL BE WIRED IN THE FOLLOWING MANNER:
- 6.A. (2) 3/4" CONDUITS FROM THE ELECTRICAL ROOM TO EACH SIGN. DO NOT LOOP CONDUITS FROM ON SIGN TO ANOTHER,
- 6.B. ON THE POLE SIGN, PROVIDE (2) 3/4" CONDUITS THAT LOOP FROM ONE LEG OF THE SIGN TO THE OTHER LEG OF THE SIGN.
- 6.C. ONE CONDUIT TO EACH SIGN SHALL HAVE (3) 120V 20 AMP CIRCUITS WITH #10 CONDUCTORS AND GROUND FOR EACH CIRCUIT. (2) CIRCUITS SHALL ALWAYS BE HOT AND ONE SHALL BE SWITCHED WITH THE EXTERIOR LIGHTING PHOTOCFIL
- 6.D. ONE CONDUIT TO EACH SIGN IS FOR FUTURE LOW VOLTAGE USE. THIS CONDUIT SHALL NOT BE LOOPED BETWEEN SIGNS.
- 6.E. THE SIGN CONDUIT SHALL NOT BE COMBINED WITH AREA LIGHTING. ALL AREA LIGHTS SHALL BE FEED THROUGH SEPARATE CONDUITS.
- 6.F. ALL BUILDING SIGNS SHALL BE INSTALLED BY THE ELECTRICAL CONTRACTOR.7. PROVIDE PERMANENT LABELS ON SWITCHES TO INDICATE LOAD SERVED.
- 8. PROVIDE 1-1/4" CONDUIT FROM NEW SATELLITE LOCATION TO CHECK OUT COUNTER. SATELLITE WILL NEED TO BE LOCATED TO A NON CANOPY LOCATION OUT THE BACK OF THE STORE.
- 9. PROVIDE 1" CONDUIT FROM CLOSET TO ALL SITE CANOPIES FOR SURVEILLANCE
- CAMERAS. COORDINATE EXACT REQUIREMENTS WITH SITE PLANS.


  10. PROVIDE 2" CONDUIT FROM OFFICE CLOSET TO 12" ABOVE ATTIC INSULATION.
- 11. INTERIOR LIGHTING CIRCUITS SHALL BE ROUTED THROUGH INTERIOR LIGHTING CONTACTOR FOR CONTROL OF ALL INTERIOR ZONES. SWITCH INDICATED SHALL BE USED FOR CONTROL OF CONTACTOR.
- 12. PROVIDE KEYLESS LIGHT FIXTURE ABOVE SCUTTLE OPENING IN ATTIC SPACE AT LOCATION INDICATED.
- 13. PROVIDE KEYLESS LIGHT FIXTURE CENTERED ABOVE WALKWAY IN ATTIC SPACE

AT LOCATION INDICATED.

PROJECT NO: 20-4047

DRAWN BY:

DATE: 8/30/2020



Prospect, Kentucky 40059
3.2691 www.cmtaegrs.com

10411 Meeting Street, Prospect, Ke 502 326.3085 f 502 326.2691 www

RCHITECTS & ASSOCIAT N HIGHWAY (502) 636-51


KEYES ARCHITE

MB OIL CO., LI 36 S. DIXIE BLVD.

\ \ E \

ELECTRICAL LIGHTING

E2.00



FOOD SERVICE KITCHEN EQUIPMENT SCHEDULE:

ITEM	ELEC.	QTY	DESCRIPTION		EL	ECTRIC	CAL				
I I LIVI	CONN.	QII	DESCINI HON	KW	HP	AMP	VOLT	PH	PLUG	HARD	REMARKS
1	•		WALK-IN BEVERAGE COOLER								MULTIPLE ACC
2	•		W.I. BEVERAGE COOLER COND. UNIT			27.0	208	3		•	
3	•		BEER CAVE COOLER								MULTIPLE ACC
4	•		BEER CAVE COND. UNIT			27.0	208	3			
5	•		ISLAND MERCHANDISER			1.0	120	1			
6	•		ISLAND MERCHANDISER COND. UNIT.			10A	208	1			
9	•		4 WELL HOT FOOD TABLE			22A	208	1	14-50P		
10	•		HOT FOOD MERCHANDISER			13.0	120	1	5-20P		
11	•		CONVECTION OVEN W/ HOLDING			12.0	120	1	5-20P		
12	•		GAS FRYER			1.7	120	1	5-20P		
13	•		GRIDDLE			0.5	120	1	5-20P		
14	•		EXHAUST HOOD								
15	•		WALK IN FREEZER							•	MULTIPLE ACC
16	•		FREEZER COND. UNIT			22.5	208	3		•	
17	•		WALK IN REFRIGERATOR							•	MULTIPLE ACC
18	•		REFRIGERATOR COND. UNIT			10	208	1		•	
19	•		REMOTE ICE MAKER			18.9	208	1		•	
20	•		ICE MAKER COND. UNIT			1.7	208	1		•	
21	•		SOLID TOP FREEZER TABLE			6.1	120	1	5-20P		
22	•		PREP TABLE			8.6	120	1	5-20P		
23	•		SODA FOUNTAIN		VERIFY	EXACT	REQUIRE	MENTS	IN FIELD	WITH	VENDOR
24	•		TEA BREWER		VERIFY	EXACT	REQUIRE	MENTS	IN FIELD	WITH	VENDOR
25	•		FREAL MIXER			15.0	120	1	5-20P		
26	•		FREAL FREEZER			15.0	120	1	5-20P		
27	•		FREEZE MACHINE			30	208	1	6-30P		
28	•		COFFEE MAKER		VERIFY	EXACT	REQUIRE	MENTS	IN FIELD	WITH	VENDOR
29	•	2	MICROWAVE			10.0	120	1	5-20P		
30	•		INDUCTION RANGE								
31	•		BAKED GOODS							$\Box$	
32	•		DONUT CASE							$\Box$	
33	•		FRAPP MACHINE							$\Box$	
34	•		CHOC CAPPU MACHINE								
35	•		CAPPUCCINO MACHINE								
36	•		THERMAL POTS	1		T T					
43	•		DISHWASHER			1				$\Box$	
47	•	3	POS TERMINALS	1		2.0	120	1	5-20P	$\Box$	
51	•	3	SUSPENDED TV MONITORS			2.0	120	1	5-20P		

### **TAGGED NOTES:**

- . PROVIDE EMERGENCY KILL SWITCH, ROUGH—IN AND STUB OUT ON EXTERIOR OF BUILDING FOR EMERGENCY PUMP SHUT DOWN. PROVIDE CONNECTION TO GAS PUMP PANEL SHUNT TRIP CONTROL AS REQUIRED. COORDINATE EXACT LOCATION FACING FILLING AREA WITH PUMP INSTALLER. COORDINATE PRIOR TO START OF CONSTRUCTION FOR UNDERGROUND ROUTING REQUIREMENTS.
- 2. ALL RECEPTACLES AND DEVICES AT THE CHECK OUT COUNTER SHALL BE MOUNTED HIGH IN THE BACK OF CASEWORK. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN.
- 3. PROVIDE 60A/250V/3P DISCONNECT IN NEMA-3R ENCLOSURE. PROVIDE ALL MOUNTING EQUIPMENT AS REQUIRED FOR MOUNTING ON WALL/ROOF. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN.
- 4. PROVIDE DISCONNECT FOR ICE CHEST AT 60" ABOVE GRADE. DISCONNEC SHALL BE PAINTED TO MATCH STOREFRONT.
- 5. PROVIDE LINE VOLTAGE CONNECTIONS TO WALK-IN COOLER THERMOSTATS AND ACCESSORIES AS REQUIRED.
- CIRCUIT INDICATED SHALL BE CONTROLLED BY A SHUNT TRIP BREAKER A REQUIRED FOR TYPE 1 EXHAUST HOOD. SHUNT TRIP SHALL BE CONTROLLED BY HOOD SHUT DOWN EQUIPMENT AS REQUIRED. COORDINATE WITH HOOD
- PROVIDE 60A/250V/3P DISCONNECT IN NEMA-3R ENCLOSURE. PROVIDE ALL MOUNTING EQUIPMENT AS REQUIRED FOR MOUNTING ON WALL/ROOF. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN.
- PROVIDE 30A/250V/2P DISCONNECT IN NEMA-3R ENCLOSURE. PROVIDE ALL MOUNTING EQUIPMENT AS REQUIRED FOR MOUNTING ON WALL. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN. PROVIDE POWER CONNECTION FROM FOUNTAIN ICE MACHINES AS REQUIRED. COORDINATE FURTHER REQUIREMENTS WITH EQUIPMENT INSTALLER.
- PROVIDE 120V CONNECTION TO GAS SOLENOID FOR SHUTDOWN OF HOOD EQUIPMENT GAS CONNECTIONS WITH SHUNT TRIP. COORDINATE EXACT LOCATION
- 10. PROVIDE RACEWAY TO MAKE UP AND EXHAUST FAN CONTROL SWITCH AS
- 11. INSTALL A LOWES 56" DIAMETER CEILING HUGGER CEILING FAN. FAN SHALL BE ALL WHITE. PROVIDE VARIABLE SPEED CONTROLLERS (LUTRON FSE-FE OR EQUAL) AT LOCATION INDICATED IN STORAGE ROOM.
- 12. NETWORK SWICHES AND PATCH PANELS SHALL BE PROVIDED BY OWNER AND LOCATED IN ELECTRICAL ROOM AS INDICATED. UNLESS OTHERWISE NOTED, PROVIDE SHIELDED, CAT 5E NETWORK CABLING FROM PHONE AND DATA DROPS INDICATED ON PLANS BACK TO THIS LOCATION. TERMINATE AND LABEL CABLING PER OWNER REQUIREMENTS. PROVIDE TELECOM UTILITY RACEWAYS FROM SITE TO RACK LOCATION. PROVIDE DEDICATED UTILITY SERVICE CONDUIT FOR LOTTERY PHONE LINE. COORDINATE EXACT REQUIREMENTS WITH OWNER AND SITE CONTRACTOR PRIOR TO ROUGH-IN. NETWORK AND VOICE CABLING SHALL BE CONTINUOUS AND SHALL NOT BE SPLICED
- 13. PROVIDE 30A/250V/3P DISCONNECT IN NEMA-3R ENCLOSURE. PROVIDE ALL MOUNTING EQUIPMENT AS REQUIRED FOR MOUNTING ON WALL/ROOF. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN.
- 14. PROVIDE CONNECTIONS TO ALL THERMOSTATS, DEFROST HEATERS AND EVAPORATOR FANS FROM CONDENSING UNIT CIRCUIT AS INDICATED. COORDINATE EXACT CONNECTION REQUIREMENTS WITH EQUIPMENT INSTALLER. PROVIDE LOCAL DISCONNECT MEANS IN COOLER IF NOT PROVIDED BY INSTALLER.
- 15. PROVIDE 120V CONNECTION TO REFRIGERATED CASE THERMOSTAT FROM CIRCUIT SERVING EXTERIOR CONDENSING UNIT. COORDINATE EXACT REQUIREMENTS WITH EQUIPMENT INSTALLER.
- 16. PROVIDE 2" CONDUIT BELOW SLAB FROM 12"X12"X4" DEEP JUNCTION BOX WITH FRONT ACCESS TO TRANSACTION COUNTER WIRING TROUGH FOR CABLING. TURN UP BELOW COUNTER IN TO WIRING TROUGH. COORDINATE EXACT LOCATION WITH CABINET INSTALLER. PROVIDE ADDITIONAL 2" CONDUIT STUBBED TO 12" ABOVE CEILING. BOX SHALL BE MOUNTED AT 12" A.F.F. FROM BOTTOM OF BOX.
- 17. PROVIDE 2" CONDUIT ABOVE CEILING FROM THE 12"X12"X4" DEEP JUNCTION BOX WITH FRONT ACCESS. BOX SHALL BE MOUNTED AT 12" A.F.F. FROM BOTTOM OF
- 18. PROVIDE INTERIOR EMERGENCY KILL SWITCH FOR EMERGENCY PUMP SHUT DOWN AT CASHIER LOCATION AS INDICATED. PROVIDE CONNECTION TO GAS PUMP PANEL SHUNT TRIP CONTROL AS REQUIRED.
- 19. PROVIDE WEATHERHEADS WHERE REQUIRED FOR TELEPHONE ENTRY AND OVERHEAD SECONDARY ELECTRICAL SERVICE WHERE REQUIRED BY UTILITY COMPANY. COORDINATE INSTALLATION WITH ALL TRADES AND WEATHER-SEAL TO MAINTAIN ROOF AND WALLS AS REQUIRED.
- 20. PROVIDE DUAL 8" X 8" X 5' ELECTRICAL TROUGHS IN ELECTRICAL ROOM FOR GAS PUMP EQUIPMENT WIRING. THE TOP TROUGH SHALL BE USED FOR LINE VOLTAGE CABLING AND THE BOTTOM TROUGH SHALL BE USED FOR LOW VOLTAGE CABLING. TROUGHS SHALL BE OFFSET FROM EACH OTHER TO ALLOW ACCESS TO EACH TROUGH.
- 21. ALL RECEPTACLES ALONG COUNTER INDICATED SHALL BE INSTALLED COMPLETELY TO THE BACK OF THE COUNTER.

0

PROJECT NO: 20-4047 DRAWN BY:

DATE:

8/30/2020

22. PROVIDE 3/4" CONDUIT DOWN TO SINGLE GANG BOX FOR ALARM SYSTEM BOX. 23. ALL CONDUIT PENETRATIONS THROUGH THE FLOOR SLAB SHALL BE PROVIDED WITH AIR TIGHT SEALS WHETHER SERVING GAS EQUIPMENT OR NOT.

- 24. PROVIDE DUPLEX RECEPTACLE IN ATTIC MOUNTED TO STRUCTURE ABOVE SCUTTLE OPENING.
- 25. PROVIDE RANGE HOOD EMERGENCY PULL CORD AT 60" ABOVE FINISHED FLOOR AT LOCATION INDICATED. REFER TO DETAIL AND COORDINATE WITH HOOD
- 26. PROVIDE A 1" CONDUIT FROM OFFICE TO EACH CANOPY ON SITE FOR CAMERA
- 27. PROVIDE A 1-1/4" CONDUIT FROM CHECKOUT COUNTER TO NEW SATELLITE LOCATION. COORDINATE EXACT TERMINATION LOCATIONS WITH OWNER PRIOR TO
- 28. PROVIDE 60A/250V/3P DISCONNECT IN NEMA-1 ENCLOSURE. COORDINATE
- 29. PROVIDE 30A/250V/3P DISCONNECT IN NEMA-1 ENCLOSURE. COORDINATE EXACT MOUNTING LOCATION WITH ALL TRADES PRIOR TO ROUGH-IN.
- 30. PROVIDE SINGLE GANG ROUGH-IN FOR SECURITY CAMERA FACING GAS CANOPY. PROVIDE 3/4" CONDUIT FROM BOX TO LOW VOLTAGE BOX ON INTERIOR SIDE OF WALL NEAR FLOOR. COORDINATE GAS CANOPY LOCATION WITH GENERAL CONTRACTOR AND INSTALL ON SIDE FACING CANOPY.

### GENERAL NEW WORK NOTES (POWER):

- A. REFER TO THE ARCHITECT'S REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF ALL CEILING MOUNTED LIGHT FIXTURES ETC. REFER ALSO TO THE ARCHITECT'S CASEWORK DETAILS AND ROOM ELEVATIONS FOR EXACT LOCATIONS AND MOUNTING HEIGHTS OF LIGHT FIXTURES, ETC.
- B. ALL NEW WIRING SHALL BE #12 WITH A #12 INSULATED GROUND WIRE (U.O.N.). CONDUIT SHALL BE 1/2" MINIMUM.
- C. CONTRACTOR SHALL FOLLOW BRANCH CIRCUITING LAY-OUT, AS INDICATED ON THE FLOOR PLANS. WITH A MAXIMUM OF THREE (3) BRANCH CIRCUITS PER HOMERUN. EACH BRANCH CIRCUIT SHALL BE PROVIDED WITH A DEDICATED NEUTRAL CONDUCTOR. DEDICATED NEUTRAL CONDUCTORS SHALL BE CONSIDERED CURRENT CARRYING. IF ADDITIONAL CONDUCTORS ARE RAN IN THE SAME CONDUIT WITH THOSE INDICATED, CONTRACTOR SHALL DERATE ALL CURRENT CARRYING CONDUCTORS PER N.E.C. #310.15(B)(3), AND UPSIZE CONDUIT AS REQUIRED PER N.E.C. #300.17 AND ANNEX C. MULTIWIRE BRANCH CIRCUITS AS DEFINED IN N.E.C #100 / 210.4 (CIRCUITS SHARING A COMMON NEUTRAL CONDUCTOR) SHALL NOT BE PERMITTED.
- D. MC CABLING SHALL BE ACCEPTABLE WHERE CONCEALED IN WALLS AND CEILINGS. EMT SHALL BE USED AT ALL EXPOSED LOCATIONS.

CONTRACTOR INDICATING ALL CONDUIT ROUTES. THE CONTRACTOR SHALL TAKE


AND PROVIDE PHOTOS OF ALL UNDERGROUND UTILITIES PRIOR TO COVERING OF F. ALL UNDERGROUND TRENCHES SHALL BE FILLED WITH STONE.

E. A DIMENSIONED AND DETAILED AS-BUILT PLAN SHALL BE PROVIDED BY THE

- G. ALL EMPTY CONDUITS FOR FUTURE USE SHALL BE PROVIDED WITH A PULL
- H. ALL DEVICES SHALL BE STAINLESS STEEL, WHITE, BROWN OR IVORY. WHITE AT WHITE AND RED TILE, BROWN AT ALL BROWN TILE AND BY STORE FRONT, IVORY AGAINST ALL PAINTED WALLS, WHITE INSIDE CABINETS AND STAINLESS AT HOOD.
- ALL CONDUITS STUBBED UP FROM FLOOR SHALL BE SEALED AS REQUIRED FOR GAS SEALS. THIS SHALL APPLY TO ALL CONDUITS WHETHER SERVING GAS EQUIPMENT OR NOT.
- J. ALL DISCONNECTS SHALL BE SQUARE D SIDE ARMED AND NON FUSED.
- K. ALL RECEPTACLES SHALL BE ON MINIMUM OF 20A CIRCUITS AND SHALL BE 20A RATED DEVICES.
- PROVIDE 3/4" AND 1" CONDUITS FROM TROUGH IN ELECTRIC ROOM TO 5'-0" BEYOND SIDEWALK AND MINIMUM OF 18" BELOW GRADE. CONDUITS TO HAVE SEAL OFF AT FIRST JOINT ABOVE FLOOR. VERIFY WITH OWNER.
- M. POLE LIGHTS AND POLES SHALL BE FURNISHED BY OWNER AND INSTALLED BY ELECTRICAL CONTRACTOR.
- N. EACH POLE LIGHT SHALL HAVE (1) DUPLEX RECEPTACLE FURNISHED AND INSTALLED BY THE ELECTRICAL CONTRACTOR. ALL POLES TO BE WIRED WITH #10 STRANDED WIRE.
- O. ALL UNDERGROUND CONDUIT SHALL HAVE GALVANIZED 90'S.
- P. PROVIDE AND INSTALL ALL CORDS AND PLUGS FOR FOOD SERVICE EQUIPMENT.
- Q. ALL GAS EQUIPMENT AND DISPENSERS MUST BE ON THE SAME PHASE (A OR C).
- R. PROVIDE (1) BREAKER FOR EACH LINE LEAK DETECTOR UST.

ELECTRICAL POWER AND SYSTEMS

E3.00



PROJECT NO: 20-4047 DRAWN BY:

BMP DATE:

8/30/2020

SOCIA

OMB NEWC

ELECTRICAL RISER DIAGRAM

E4.00

PANELI	BOARD:		В		AMPERES:	225	VOLTAGE	120/2	80	P	HASE	3		WIRE:	4	MANUF.:	SQUAF	RE D	TYPE	MOD	ULAR	
			LOAD																LOAD			
GND	CON	Α	В	С	DESIGNATIO	N		WIRE	BKR	CKT		CKT	BKR	WIRE	DESIGNAT	ION		Α	В	С	CON	GNE
12	3/4"	1.0			RESTROOM -	- RCP		12	GFI	1		2	20/1	12	OFFICE -RO	CP		1.2			3/4"	12
12	3/4"		1.0		STORAGE - I	RCP		12	20/1	3		4	20/1	12	CASH REG	SISTER - RCP			0.6		3/4"	12
12	3/4"			1.0	CASH REGIS	TER - RCP	h	12	20/1	5		6	20/1	12	CASH REG	SISTER - RCP				0.8	3/4"	12
12	3/4"	1.2			STOREFRON	IT - RCP		12	20/1	7		8	20/1	12	STOREFRO	ONT - RCP		1.0			3/4"	12
12	3/4"		1.0		HAND DRY E	R - MENS		12	GFI	9		10	20/1	12	LOTTERY				0.4		3/4"	12
12	3/4"			1.0	HAND DRY E	R - WOME	VS	12	GFI	11		12	GFI	12	EXTERIOR	RECEPTACLES -	REAR			0.4	3/4"	12
12	3/4"	0.6			STORAGE - I	RCP		12	20/1	13		14	GFI	12	RESTROOM	M - RCP		0.6			3/4"	12
12	3/4"		0.6		STORAGE - I	ROP		12	20/1	15		16	20/2	12	FOUNTAIN	ICE MACHINE			1.2		3/4"	12
12	3/4"			0.6	STORAGE - I	ROP		12	20/1	17		18								1.2		
12	3/4"	0.6			STORAGE - I	ROP		12	20/1	19		20	20/1	12	WH-1			1.0			3/4"	12
12	3/4"		0.9		CEILING FAN	IS		12	20/1	21		22	20/1		SPARE							
12	3/4"			0.4	TELECOM - F	RCP		12	20/1	23		24	20/1	12	STORE - R	CP				1.0	3/4"	12
12	3/4"	1.2			DELI CASE -	COMPRES	SOR	12	20/2	25		26	30/3	10	WALK-IN F	REEZER - COMP		2.7			3/4"	10
			1.2	1						27		28							2.7			
					SPARE				20/1	29		30								2.7		
10	3/4"	3.2			BEER CAVE	COMPRES	SOR	8	40/3	31		32	20/1	12	WALK-IN F	REEZER - DOOR	2	0.5			3/4"	12
			3.2							33		34	20/1	12	COUNTER	- ROP			0.6		3/4"	12
				3.2						35		36	20/2	12	FOUNTAIN	ICE MACHINE				1.2	3/4"	12
10	3/4"	3.2			WALK-IN BE	V. COOLE	R COMP.	8	40/3	37		38						1.2				
			3.2							39		40	20/1	12	FOUNTAIN	SIGNS			0.1		3/4"	12
				3.2						41		42	20/1	12	∞FFEE T\	/'S				0.4	3/4"	12
10	1"	5.6			DISHWASHE	R		6	60/3	43		44	20/1		SPARE							
			5.6							45		46	20/1		SPARE							
				5.6						47		48	20/1		SPARE							
					SPD					49		50	20/1		SPARE							
										51		52	20/1		SPARE							
										53		54	20/1		SPARE							
		16.6	16.7	15.0	SUB-TOTAL		KVA			•					KVA	SUB-TOTAL	_	8.2	5.6	7.7		
							-	•							KVA	GROSS-TO	TAL	24.8	22.3	22.7		69
EME	RGENCY	POWER	₹:	NO				MAIN E	BREAK	ER:												
BRA	NCH:							MAINL					YES		A.I.C. RAT	NO. 10 000						

A NELI	BOARD:		C		AMPERES:	225	VOLTAGE:	120/2	80	PH	HASE:	3		WIRE:	4	MANUF.:	SQUA	RE D	TYPE	MOD	ULAR	
			LOAD																LOAD			
GND	CON	Α	В	С	DESIGNATIO	DN		WIRE	BKR	CKT		CKT	BKR	WIRE	DESIGNATION DESIGNATION	NC		Α	В	С	CON	GND
12	3/4"	1.2			COFFEE BRE	EWER		12	GFI	1		2	GFI	12	TEA MACH	NE		1.0			3/4"	12
12	3/4"		0.2		BACK DELIV	WALL RCP		12	GFI	3		4	GFI	12	FOUNTAIN	WALL RCP			0.2		3/4"	12
12	3/4"			1.2	COFFEE BRE	EWER		12	GFI	5		6	GFI	12	FOUNTAIN	MACHINE				1.0	3/4"	12
12	3/4"	0.2			BACK DELIV	WALL ROP		12	GFI	7		8	GFI	12	FOUNTAIN	WALL RCP		0.2			3/4"	12
12	3/4"		1.0		TOASTER - I	RCP		12	GFI	9		10	30/1	10	CA PPUCCIN	Ю			1.0		3/4"	10
12	3/4"			1.5	INDUCTION F	RANGE - RO	P	12	GFI	11		12	30/1	10	CHOCOLAT	E CA PPUCCINO	)			1.0	3/4"	10
12	3/4"	1.0			BACK DELIV	WALL ROP		12	GFI	13		14	GFI	12	FRA PPE MA	CHINE		1.0			3/4"	12
12	3/4"		1.0		BAKED GOO	DDS RECEPT	TACLE	12	GFI	15		16	GFI	12	COFFEE WA	ARMER			1.0		3/4"	12
12	3/4"			1.2	FROZEN CA	RB. BEVER	AGE	12	20/2	17		18	GFI	12	FOUNTAIN	WALL RCP				0.2	3/4"	12
		1.2						1		19		20	GFI	12	FREAL FRE	EZER		1.2			3/4"	12
12	3/4"		1.2		FREAL MIXE	R		12	GFI	21		22	20/3	12	MAUCOMP	RESSOR			0.8		3/4"	12
12	3/4"			1.0	MICROWAVE	E		12	20/1	23		24								0.8		
12	3/4"	1.0			BEER CAVE	DOORS		12	20/1	25		26						0.8				
12	3/4"		1.0		COOLER DO	ORS		12	20/1	27		28	GFI	12	MICROWAV	′E			1.2		3/4"	12
12	3/4"			1.0	BEER CAVE	EVA PORA	TOR	12	20/1	29		30	30/1	10	MAUFAN					1.9	3/4"	10
12	3/4"	1.5			COOLER EV	APORATOR	?	12	20/1	31		32	GFI	12	COFFEE W/	ARMER		1.0			3/4"	12
12	3/4"		1.5		COOLER EV	APORATOR	?	12	20/1	33		34	GFI		SPARE							12
12	3/4"			1.0	ICE CHEST			12	GFI	35		36	GFI	12	FREEZER -	RCP				1.0	3/4"	12
12	3/4"	1.0			ICE CHEST			12	GFI	37		38	GFI	12	REFRIGERA	TED CASE		0.4			3/4"	12
12	3/4"		0.2		FOUNTAIN V	VALL RCP		12	GFI	39		40	50/2	8	STEAMTA	BLE			2.6		3/4"	10
12	3/4"			0.2	FOUNTAIN V	VALL RCP		12	GFI	41		42								2.6		
10	3/4"	1.7			ICEMAKER -	INDOOR UN	JIT	10	20/2	43	_	44	GFI	12	FRONT DEL	I WALL RECEP	TACLE	0.2			3/4"	12
			1.7					1222		45		46	GFI	12	REFRIGERA	TED PREP TAB	BLE		1.0		3/4"	12
12	3/4"			1.0	COFFEE WA	RMER		12	GFI	47		48	GFI	12	CA RBONA	TION PUMPS				1.0	3/4"	12
					SPD					49		50	30/1	10	HOOD EXH	AUSTFAN		1.9			3/4"	10
										51		52	20/1	12	DELI ISLAN	D-RCP			1.0		3/4"	12
										53		54	20/1		SPARE							
		8.8	7.8	8.1	SUB-TOTAL	_	KVA								KVA	SUB-TOTA	<b>L</b>	7.7	8.8	9.5		
							1								KVA	GROSS-TO	TAL	16.5	16.6	17.6		50.
EME	RGENCY	POWER	:	NO				MA IN E	DDEA IZI	ED.						•			•			


PA NEL	BOARD:		D		AMPERES:	225	VOLTAGE:	120/20	08	Pł	ASE:	3		WRE:	4	MANUF.: SO	QUARE D	TY PE:	MOD	ULAR	
			LOAD															LOAD			
GND	CON	Α	В	С	DESIGNATIO	N		WIRE	BKR	СКТ		CKT	BKR	WRE	DESIGNATI	ON	Α	В	С	CON	GN
12	3/4"	1.2			CUSTOMER	AREA - LTO	G	12	20/1	1	-	2	20/1	12	COUNTER A	AREA - LTG	0.9			3/4"	12
					SPARE				20/1	3		4	20/1	12	GRA PHICS	- LTG		0.5		3/4"	12
12	3/4"			1.0	GRAPHICS -	LTG		12	20/1	5		6	20/1	12	GRA PHICS	- LTG			1.0	3/4"	12
12	3/4"	0.4			ΟΟVE- LTG			12	20/1	7		8	20/1	12	COOLER-I	_TG	0.3			3/4"	12
12	3/4"		1.3		BACK ROOM	M - LTG		12	20/1	9		10	20/1	12	EMERGENO	Y LIGHTING		0.1		3/4"	12
12	3/4"			1.2	P-1			12	20/1	11		12	20/1	12	HOOD LIGH	пѕ			0.2	3/4"	12
12	3/4"	1.5			HOT SANDV	VICH CASE	208V	12	20/2	13		14	20/3	12	DISPOSAL		0.6			3/4"	12
			1.5							15		16						0.6			
12	3/4"			1.5	HOT SANDV	VICH CASE	120V	12	20/1	17		18							0.6		
					SPARE				20/1	19		20	20/1	10	SITE POLE	RECEPTA CLES	1.2			3/4"	10
					SPARE				20/1	21		22	20/1		SPARE						
					SPARE				20/1	23		24	20/1		SPARE						
					SPARE				20/1	25		26	20/2	10	COOLER - 0	COMPRESSOR	1.2			3/4"	10
12	3/4"		1.0		BACK OF H	OUSE - LTG	3	12	20/1	27		28						1.2			
					SPARE				20/1	29		30	20/1		SPARE						
					SPARE				20/1	31		32	20/1		SPARE						
					SPARE				20/1	33		34	20/1		SPARE						
					SPARE				20/1	35		36	20/1		SPARE						
					SPARE				20/1	37		38	20/1		SPARE						
					SPARE				20/1	39		40	20/1		SPARE						
					SPARE				20/1	41		42	20/1		SPARE						
					SPARE				20/1	43		44	20/1		SPARE						
					SPARE				20/1	45		46	20/1		SPARE						
					SPARE				20/1	47		48	20/1		SPARE						
					SPD					49		50	20/1		SPARE						
										51		52	20/1		SPARE						
										53		54	20/1		SPARE						
		3.1	3.8	3.7	SUB-TOTAL		KVA								KVA	SUB-TOTAL	4.2	2.4	1.8		
															KVA	GROSS-TOTAL	7.3	6.2	5.5		19
EME	RGENCY	POWER	₹:	NO				MAINE	BREAK	ER:											


PA NEL	BOARD:		D1		AMPERES:	225	VOLTAGE	120/2	08	Ph	ASE:	3		WIRE:	4	MANUF.: \$	QUARE D	TY PE:	MOD	ULAR	
GND	CON	A	LOAD B	С	DESIGNATION	N		WIRE	BKR	СКТ		СКТ	BKR	WIRE	DESIGNATION	ON		LOAD	С	CON	GNE
			В	C							-			_				В			
12	3/4"	0.2			BUILDING SIG			12	20/1	1	-	2	50/3	8	FRYER		4.7			3/4"	10
12	3/4"		0.5	0.0	BUILDING CA			12	20/1	3		4						4.7	4.7		
12	3/4"	15		0.2	BUILDING MC		_IG	12	20/1	5		6	40/2		OVEN / DBC	OCEED	2.5		4.7	2/4"	10
10	3/4"	1.5	1.5		SITE POLE LIK			10	20/1	7		10	40/3	8	OVEN / PRO	DOFER	3.5	3.5		3/4"	
10	3/4"		1.0	1.5	SITE POLE LIK			10	20/1	11		12						3.0	3.5		
10	1"	1.2		1.0	SITESIGN	01110		10	20/1	13	-	14	20/1	12		LDING CABINET	2.0		3.5	3/4"	12
10	1"	1.2	1.2		SITESIGN			10	20/1	15		16	40/2	8	GRIDDLE	EDITO OTENIET	2.0	3.5		3/4"	10
12	3/4"		1.2	1.0	THERMAL SE	RVER		12	20/1	17		18						3.5	3.5		
12	3/4"	1.0			THERMAL SE			12	20/1	19		20	20/1	12	THERMAL S	SERVER	1.0			3/4"	12
12	3/4"		1.0		OVEN / PROC	OFER		12	GFI	21		22	20/1	12	EXT. LIGHTI	ING CONTROL		0.0		3/4"	12
12	3/4"			1.0	OVEN / PROC	DFER		12	GFI	23		24	20/1		SPARE						
12	3/4"	1.0			FRY ER			12	20/1	25		26	40/3	8	OVEN / PRO	DOFER	3.5			3/4"	10
12	3/4"		1.0		GRIDDLE			12	20/1	27		28						3.5			
					SPARE				20/1	29	1	30							3.5		
					SPARE				20/1	31		32	20/1		SPARE						
					SPARE				20/1	33	1	34	20/1		SPARE						
					SPARE				20/1	35		36	20/1		SPARE						
					SPARE				20/1	37		38	20/1		SPARE						
					SPARE				20/1	39	]	40	20/1		SPARE						
					SPARE				20/1	41		42	20/1		SPARE						
					SPARE				20/1	43		44	20/1		SPARE						
					SPARE				20/1	45		46	20/1		SPARE						
					SPARE				20/1	47		48	20/1		SPARE						
					SPARE				20/1	49		50	20/1		SPARE						
					SPARE				20/1	51		52	20/1		SPARE						
					SPARE				20/1	53		54	20/1		SPARE						
		4.9	5.2	3.7	SUB-TOTAL		KVA								KVA	SUB-TOTAL	14.7	15.2	15.2		
															KVA	GROSS-TOTA	L 19.6	20.4	18.9		58

ELECTRICAL DETAILS
NO SCALE

PROJECT NO: 20-4047 DRAWN BY: 3MP

DRAWN BY:
BMP
DATE:
8/30/2020





KEYES ARCHITECTS & ASSOCIATI
4717 PRESTON HIGHWAY

NEWCOMB OIL CO., LLC

ELECTRICAL SCHEDULES