

DATE: July 8, 2021

RE: Family Allergy
500 W. Jefferson St. Suite 160
Louisville, KY

SUBJECT: Addendum 1

TO: All Contract Bidders

The following shall be included in Contract Drawings and Specifications on the above referenced project. Contractors shall acknowledge receipt of this revision.

Electrical

1. Reference Drawing E1.1 and include the following:
 - a. Revised circuit numbers from '1BC' to 'FA'.
2. Reference Drawing E2.1 and include the following:
 - a. Revised circuit numbers from '1BC' to 'FA'.
 - b. Changed panel from '1BC' to 'FA'. Panel located in electrical room between elevators. Field Verify exact location in room.
3. Reference Drawing E3.1 and include the following:
 - a. Revised panel schedule from '1BC' to 'FA'.
 - b. Changed one line diagram to represent the new panel 'FA'. Removed panel '1BC'.
 - c. Changed Keyed Note 2 for new panel 'FA'.

END OF ADDENDUM

I:\20218074_FAMILY_ALLERGY_&_ASTHMA\DESIGN\ISSUED DOCUMENTS\2021-07-08 ADDENDUM 1\2021-07-08_FAMILY ALLERGY_ADDENDUM_1.doc