
Addendum Number One

**Elizabethtown Freeman Lake Park
Shelters Project**
Freeman Lake Park Drive
Elizabethtown, Kentucky

Wednesday, January 17, 2024

TO: All Planholders of Record

This Addendum forms part of the Procurement Documents and modifies the original Procurement Documents dated December 22, 2023, as defined herein. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification. This Addendum consists of three (3) pages, inclusive of one (1) page of attachments.

1. GENERAL – BIDDER QUESTIONS

The following are Bidder Questions and CMW Responses.

A. QUESTION: Can you confirm the restroom building and pavilion shelter are structurally independent buildings?

RESPONSE: Yes, the pavilion is elevated above the restroom building and has independent below grade footings. See Elevations on Sheet A-201.

B. QUESTION: Where is the product information for the specified attic access panel “Nystrom IT series”? Will alternate access panels be accepted?

RESPONSE: Attached to this addendum is a cut sheet of the Nystrom Access Panel. Yes, alternate access panels may be substituted upon approval of the architect.

C. QUESTION: Is there a particular vendor that the city has used to source the gable sign?

RESPONSE: The Gable Sign shown on Detail 3, Sheet A-302 is to be removed from the project and is N.I.C.

D. QUESTION: Are fire extinguishers required in this scope of work?

RESPONSE: Yes, Provide Fire Extinguisher with mounting bracket on plan south wall of Utility 102 – Keynote 1, Sheet A-101.

E. QUESTION: May a standard wooden Tongue & Groove secured to steel may be used in lieu of the “Knotwood”?

RESPONSE: Yes, 2x6 tongue and groove (T&G), southern yellow pine, kiln dried #1 grade or better, boards with edge V'd bottom side, stained, may be used.

2. DIVISION 0 – PROCUREMENT

CITY OF ELIZABETHTOWN FRONT-END SPECIFICATIONS

A. N/A

3. DIVISIONS 03 through 33 – TECHNICAL SPECIFICATIONS

A. 265100 – INTERIOR LIGHTING

a. Refer to Equal Manufacturers:

i. Based on representation by the manufacturer and Bidder that the function, performance, fabrication, installation, appearance, quality, and warranty are equivalent or superior to the specified items, the following proposed substitution equipment manufacturer is acceptable for the equipment indicated but still subject to Submittal Review:

1. *Fixture A2: Kim PVNT*
2. *Fixture A4: Kim PVNT*
3. *Fixture B: Beacon RWL1*
4. *Fixture C4: Kim PVNT*
5. *Fixture EM: Dual Lite EV4D*

4. DRAWINGS

A. N/A

5. LIST OF ATTACHMENTS

A. Nystrom Access Panel cut sheet.

End of Addendum Number One



CMW Architects & Engineers
Architecture • Interior Design • Engineering • Landscape Architecture
p: 859.254.6623 **w:** cmwaec.com
a: 249 East Main Street; Suite 100 • Lexington, Kentucky • 40507

Insulated Fire-Rated ACCESS DOOR

Designed for wall and ceiling applications, this fire-rated Insulated Access Door is UL and Warnock-Hersey listed. Engineered with mineral fiber to assist in reducing heat transfer in the event of a fire.

FEATURES

FIRE-RATED Independently tested and labeled for 1-1/2 hours for wall applications and 3 hours for ceiling applications.

EASY OPERATION This self-closing door features an inside knurled knob latch release is easy to operate.

CUSTOM SIZING Custom sizes available from 6 inches by 6 inches to 48 inches by 48 inches.



DETAILS

DOOR 20 gauge Steel, Self-Closing

FRAME 16 gauge Steel

SIZE

- Min: 6 inches by 6 inches
- IT Max: 24 inches by 72 inches or 48 inches by 48 inches
- IW/IP Max: 36 inches by 48 inches

INSTALLATION Ceiling or Wall

HINGE

- IT: Flush Continuous Piano
- IW/IP: Concealed Pin

FINISH White Powder Coat

INSULATION 2 inch Thick, Fire-Rated Mineral Fiber, R-8

CERTIFICATION

- UL listed "B" label for 1-1/2 hours (Wall)
- Warnock-Hersey listed for 3 hours (Ceiling)

ORDER GUIDE

BASE	FLANGE	LATCH	WIDTH	X	LENGTH	OPTIONS
I				X		
	T 1 inch Flange W Drywall Bead P Plaster Bead	K Knurled Knob / Key Operated Latch Bolt M Mortise Lock (1-1/8") Prep	Standard Sizes (W x L) 8" x 8" 18" x 24" 24" x 48" 10" x 10" 20" x 30" 30" x 30" 12" x 12" 22" x 22" 32" x 32" 12" x 18" 22" x 30" 36" x 36" 12" x 24" 22" x 36" 36" x 48" 14" x 14" 24" x 24" 48" x 48" 16" x 16" 24" x 30" 18" x 18" 24" x 36"			B Galvannealed G Gasketing M Masonry Anchors S Stainless Steel, Type 304

Rough opening is door size + 1/4 inch minimum. Additional sizes available, call for more information.
*Wall application only.

MATERIALS



White
Powder Coat


FLANGES



1 inch Flange



Drywall Bead



Plaster Bead

LATCHES



Knurled
Knob



Mortise
Lock Prep