

April 28, 2025

Golightly & Long Properties, LLC
5280 Cairo Road
Paducah, KY 42001

BIDDING ADDENDUM 4

For work titled:
Acee's Neighborhood Market & Deli
1000 Holiday Lane
Fulton, KY 42041
Project Number: 23-7038

TO ALL BIDDERS

GENERAL NOTES

This addendum is issued for the purpose of clarifying the intent of the contract documents or for making necessary corrections, deletions, and/or additions to the documents on all items of discrepancy raised up to the time of the issuance of this addendum.

Each bidder is hereby instructed and authorized to incorporate into his proposal the instructions contained in this addendum. This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, dated March 17, 2025 . Acknowledge receipt of this addendum in space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

This addendum consists of (one) (1) – 8-1/2" x 11" pages including this cover sheet

DRAWINGS

1. Sheet C601	REVISE detail 1/C601 note from Addenda 3 should read: "The owner is responsible for hiring a 3 rd party to perform a tank tightness test on the fuel tanks per KYOSFM regulations. The OWNER is responsible for ballasting the fuel tanks with WATER/FUEL and DEF tank with DEF on the day of installation, the contractor shall coordinate ballasting of tanks with the owner. The owner is responsible for getting all water completely pumped out of the fuel tanks prior to them being filled with fuel".
2. Sheet E101	CLARIFICATION the contractor shall provide GFI receptacles in Shower 1 & Shower 2, as well as other locations on the plans as required by the NEC.

ATTACHMENTS - None

All other terms and conditions of the Project Manual and Drawings shall remain unchanged.

END OF ADDENDUM 4